

4MXM80A

230V 50Hz calefacción

Unidad exterior	Unidad interior	Capacidad de calefacción [kW]				Capacidad total [kW]			Consumo [kW]			Corriente total [A]			Factor de potencia [%]
		Ambiente A	Ambiente B	Ambiente C	Ambiente D	Mínimo	Nominal	Máxima	Mínimo	Nominal	Máxima	Mínimo	Nominal	Máxima	
4MXM80M2V1B	1.5+1.5+3.5+3.5	1.44	1.44	3.36	3.36	3.39	9.60	11.22	0.55	2.14	2.69	2.60	9.80	12.31	95
	1.5+1.5+3.5+4.2	1.35	1.35	3.14	3.77	3.55	9.60	11.23	0.57	2.11	2.65	2.70	9.70	12.13	95
	1.5+1.5+3.5+5.0	1.25	1.25	2.92	4.17	3.86	9.60	11.30	0.62	2.04	2.58	2.90	9.40	11.90	95
	1.5+1.5+3.5+6.0	1.15	1.15	2.69	4.61	4.18	9.60	11.51	0.67	2.04	2.66	3.20	9.40	12.15	95
	1.5+1.5+4.2+7.1	1.06	1.06	2.47	5.01	4.49	9.60	11.65	0.73	2.03	2.70	3.40	9.30	12.35	95
	1.5+1.5+4.2+4.2	1.26	1.26	3.54	3.54	3.87	9.60	11.23	0.62	2.08	2.61	2.90	9.60	11.97	95
	1.5+1.5+4.2+5.0	1.18	1.18	3.30	3.93	4.01	9.60	11.37	0.64	2.02	2.58	3.00	9.30	11.82	95
	1.5+1.5+4.2+6.0	1.09	1.09	3.05	4.36	4.33	9.60	11.57	0.70	2.02	2.64	3.30	9.30	12.20	95
	1.5+1.5+4.2+7.1	1.01	1.01	2.82	4.77	4.65	9.60	11.66	0.76	2.01	2.67	3.50	9.30	12.24	95
	1.5+1.5+5.0+5.0	1.11	1.11	3.69	3.69	4.32	9.60	11.49	0.69	1.98	2.57	3.20	9.10	11.77	95
	1.5+1.5+5.0+6.0	1.03	1.03	3.43	4.11	4.48	9.60	11.76	0.72	1.98	2.67	3.30	9.10	12.20	95
	1.5+2.0+2.0+2.0	1.90	2.53	2.53	2.53	2.74	9.50	10.67	0.44	2.12	2.49	2.10	9.80	11.38	95
	1.5+2.0+2.0+2.5	1.80	2.40	2.40	3.00	2.90	9.60	10.81	0.46	2.14	2.53	2.20	9.80	11.58	95
	1.5+2.0+2.0+3.5	1.60	2.13	2.13	3.73	3.23	9.60	11.22	0.52	2.14	2.69	2.40	9.80	12.31	95
	1.5+2.0+2.0+4.2	1.48	1.98	1.98	4.16	3.39	9.60	11.23	0.54	2.11	2.65	2.60	9.70	12.13	95
	1.5+2.0+2.0+5.0	1.37	1.83	1.83	4.57	3.53	9.60	11.30	0.56	2.04	2.58	2.60	9.40	11.90	95
	1.5+2.0+2.0+6.0	1.25	1.67	1.67	5.01	3.85	9.60	11.51	0.61	2.04	2.66	2.90	9.40	12.15	95
	1.5+2.0+2.0+7.1	1.14	1.52	1.52	5.41	4.17	9.60	11.57	0.67	2.03	2.66	3.20	9.30	12.30	95
	1.5+2.0+2.5+2.5	1.69	2.26	2.82	2.82	3.07	9.60	10.81	0.49	2.13	2.52	2.30	9.80	11.55	95
	1.5+2.0+2.5+3.5	1.52	2.02	2.53	3.54	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.80	12.20	95
	1.5+2.0+2.5+4.2	1.41	1.88	2.35	3.95	3.55	9.60	11.23	0.57	2.10	2.64	2.70	9.70	12.10	95
	1.5+2.0+2.5+5.0	1.31	1.75	2.18	4.36	3.69	9.60	11.30	0.59	2.04	2.57	2.80	9.40	11.90	95
	1.5+2.0+2.5+6.0	1.20	1.60	2.00	4.80	4.01	9.60	11.51	0.64	2.03	2.65	3.00	9.40	12.13	95
	1.5+2.0+2.5+7.1	1.10	1.47	1.83	5.20	4.33	9.60	11.57	0.70	2.03	2.66	3.30	9.30	12.20	95
	1.5+2.0+3.5+3.5	1.37	1.83	3.20	3.20	3.56	9.60	11.22	0.57	2.13	2.68	2.70	9.80	12.27	95
	1.5+2.0+3.5+4.2	1.29	1.71	3.00	3.60	3.71	9.60	11.23	0.60	2.10	2.64	2.80	9.70	12.10	95
	1.5+2.0+3.5+5.0	1.20	1.60	2.80	4.00	4.02	9.60	11.30	0.64	2.04	2.57	3.00	9.40	11.90	95
	1.5+2.0+3.5+6.0	1.11	1.48	2.58	4.43	4.17	9.60	11.51	0.67	2.03	2.65	3.20	9.40	12.13	95
	1.5+2.0+3.5+7.1	1.02	1.36	2.38	4.83	4.49	9.60	11.65	0.73	2.03	2.69	3.40	9.30	12.33	95
	1.5+2.0+4.2+4.2	1.21	1.61	3.39	3.39	4.03	9.60	11.24	0.65	2.08	2.61	3.10	9.60	11.94	95
	1.5+2.0+4.2+5.0	1.13	1.51	3.17	3.78	4.17	9.60	11.37	0.67	2.02	2.58	3.10	9.30	11.80	95
	1.5+2.0+4.2+6.0	1.05	1.40	2.94	4.20	4.49	9.60	11.57	0.73	2.01	2.64	3.40	9.30	12.10	95
	1.5+2.0+5.0+5.0	1.07	1.42	3.56	3.56	4.32	9.60	11.48	0.69	1.98	2.57	3.20	9.10	11.75	95
	1.5+2.0+5.0+6.0	0.99	1.32	3.31	3.97	4.63	9.60	11.75	0.75	1.99	2.66	3.50	9.20	12.18	95
	1.5+2.5+2.5+2.5	1.60	2.67	2.67	2.67	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.80	12.10	95
	1.5+2.5+2.5+3.5	1.44	2.40	2.40	3.36	3.39	9.60	11.15	0.54	2.13	2.64	2.60	9.80	12.10	95
	1.5+2.5+2.5+4.2	1.35	2.24	2.24	3.77	3.55	9.60	11.23	0.57	2.10	2.64	2.70	9.60	12.07	95
	1.5+2.5+2.5+5.0	1.25	2.09	2.09	4.17	3.85	9.60	11.30	0.61	2.03	2.56	2.90	9.40	11.80	95
	1.5+2.5+2.5+6.0	1.15	1.92	1.92	4.61	4.17	9.60	11.51	0.67	2.03	2.64	3.20	9.30	12.10	95
	1.5+2.5+2.5+7.1	1.06	1.76	1.76	5.01	4.49	9.60	11.57	0.73	2.02	2.65	3.40	9.30	12.20	95
1.5+2.5+3.5+3.5	1.31	2.18	3.05	3.05	3.72	9.60	11.22	0.60	2.13	2.67	2.80	9.80	12.24	95	
1.5+2.5+3.5+4.2	1.23	2.05	2.87	3.45	3.87	9.60	11.23	0.63	2.10	2.64	2.90	9.60	12.07	95	
1.5+2.5+3.5+5.0	1.15	1.92	2.69	3.84	4.17	9.60	11.30	0.67	2.03	2.56	3.20	9.40	11.80	95	
1.5+2.5+3.5+6.0	1.07	1.78	2.49	4.27	4.33	9.60	11.51	0.70	2.03	2.64	3.30	9.30	12.10	95	
1.5+2.5+4.2+4.2	1.16	1.94	3.25	3.25	4.02	9.60	11.24	0.65	2.07	2.60	3.00	9.50	11.91	95	
1.5+2.5+4.2+5.0	1.09	1.82	3.05	3.64	4.33	9.60	11.37	0.70	2.01	2.57	3.30	9.30	11.78	95	
1.5+2.5+4.2+6.0	1.01	1.69	2.84	4.06	4.65	9.60	11.57	0.75	2.01	2.63	3.50	9.30	12.10	95	
1.5+2.5+5.0+5.0	1.03	1.71	3.43	3.43	4.48	9.60	11.48	0.72	1.98	2.56	3.30	9.10	11.73	95	
1.5+3.5+3.5+3.5	1.20	2.80	2.80	2.80	4.04	9.60	11.22	0.66	2.13	2.67	3.10	9.80	12.24	95	
1.5+3.5+3.5+4.2	1.13	2.65	2.65	3.17	4.19	9.60	11.23	0.68	2.10	2.64	3.20	9.60	12.07	95	
1.5+3.5+3.5+5.0	1.07	2.49	2.49	3.56	4.33	9.60	11.37	0.70	2.03	2.60	3.30	9.40	11.90	95	
1.5+3.5+3.5+6.0	0.99	2.32	2.32	3.97	4.65	9.60	11.57	0.76	2.03	2.66	3.50	9.30	12.20	95	
1.5+3.5+4.2+4.2	1.07	2.51	3.01	3.01	4.34	9.60	11.24	0.71	2.07	2.60	3.30	9.50	11.91	95	
1.5+3.5+4.2+5.0	1.01	2.37	2.84	3.38	4.65	9.60	11.37	0.76	2.01	2.57	3.50	9.30	11.78	95	
1.5+4.2+4.2+4.2	1.02	2.86	2.86	2.86	4.50	9.60	11.24	0.73	2.05	2.57	3.40	9.40	11.76	95	
2.0+2.0+2.0+2.0	2.40	2.40	2.40	2.40	2.90	9.60	10.88	0.46	2.10	2.55	2.20	9.60	11.70	95	
2.0+2.0+2.0+2.5	2.26	2.26	2.26	2.82	3.07	9.60	10.95	0.49	2.13	2.58	2.30	9.80	11.79	95	
2.0+2.0+2.0+3.5	2.02	2.02	2.02	3.54	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.80	12.20	95	
2.0+2.0+2.0+4.2	1.88	1.88	1.88	3.95	3.55	9.60	11.23	0.57	2.10	2.64	2.70	9.70	12.10	95	
2.0+2.0+2.0+5.0	1.75	1.75	1.75	4.36	3.69	9.60	11.30	0.59	2.04	2.57	2.80	9.40	11.90	95	
2.0+2.0+2.0+6.0	1.60	1.60	1.60	4.80	4.01	9.60	11.51	0.64	2.03	2.65	3.00	9.40	12.13	95	
2.0+2.0+2.0+7.1	1.47	1.47	1.47	5.20	4.33	9.60	11.57	0.70	2.03	2.66	3.30	9.30	12.20	95	
2.0+2.0+2.5+2.5	2.13	2.13	2.67	2.67	3.23	9.60	11.15	0.52	2.13	2.64	2.40	9.80	12.10	95	
2.0+2.0+2.5+3.5	1.92	1.92	2.40	3.36	3.39	9.60	11.15	0.54	2.13	2.64	2.60	9.80	12.10	95	
2.0+2.0+2.5+4.2	1.79	1.79	2.24	3.77	3.55	9.60	11.23	0.57	2.10	2.64	2.70	9.60	12.07	95	
2.0+2.0+2.5+5.0	1.67	1.67	2.09	4.17	3.85	9.60	11.30	0.61	2.03	2.57	2.90	9.40	11.80	95	
2.0+2.0+2.5+6.0	1.54	1.54	1.92	4.61	4.17	9.60	11.51	0.67	2.03	2.64	3.20	9.30	12.10	95	
2.0+2.0+2.5+7.1	1.41	1.41	1.76	5.01	4.49	9.60	11.57	0.73	2.02	2.65	3.40	9.30	12.20	95	
2.0+2.0+3.5+3.5	1.75	1.75	3.05	3.05	3.72	9.60	11.22	0.60	2.13	2.67	2.80	9.80	12.24	95	
2.0+2.0+3.5+4.2	1.64	1.64	2.87	3.45	3.87	9.60	11.23	0.63	2.10	2.64	2.90	9.60	12.07	95	
2.0+2.0+3.5+5.0	1.54	1.54	2.69	3.84	4.17	9.60	11.30	0.67	2.03	2.57	3.20	9.40	11.80	95	
2.0+2.0+3.5+6.0	1.42	1.42	2.49	4.27	4.33	9.60	11.51	0.70	2.03	2.64	3.30	9.30	12.10	95	
2.0+2.0+4.2+4.2	1.55	1.55	3.25	3.25	4.02	9.60	11.24	0.65	2.07	2.60	3.00	9.50	11.91	95	
2.0+2.0+4.2+5.0	1.45	1.45	3.05	3.64	4.33	9.60	11.37	0.70	2.01	2.57	3.30	9.30	11.78	95	
2.0+2.0+4.2+6.0	1.35	1.35	2.84	4.06	4.65	9.60	11.57	0.75	2.01	2.63	3.50	9.30	12.10	95	
2.0+2.0+5.0+5.0	1.37	1.37	3.43	3.43	4.48	9.60	11.48	0.72	1.98	2.56	3.30	9.10	11.74	95	
2.0+2.5+2.5+2.5	2.02	2.53	2.53	2.53	3.23	9.60	11.15	0.52	2.12	2.63	2.40	9.80	12.10	95	
2.0+2.5+2.5+3.5	1.83	2.29	2.29	3.20	3.55	9.60	11.15	0.57	2.12	2.63	2.70	9.80	12.10	95	
2.0+2.5+2.5+4.2	1.71	2.14	2.14	3.60	3.71	9.60	11.16	0.60	2.09	2.59	2.80	9.60	11.90	95	