

4MXM80A8

Heating · 230V 50Hz·

Outdoor unit	Indoor unit	Heating capacity [kW]				Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room ·A·	Room ·B·	Room ·C·	Room ·D·	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
4MXM80M2V1B 4MXM80N2V1B 4MXM80N2V1B9 4MXM80A2V1B 4MXM80A2V1B9 4MXM80A2V1B8	2.0+2.0+2.5	2.46	2.46	3.08	-	2.38	8.00	10.55	0.47	1.83	2.80	2.15	8.40	12.81	95
	2.0+2.0+3.5	2.40	2.40	4.20	-	2.81	9.00	10.68	0.46	2.19	2.86	2.20	10.10	13.08	95
	2.0+2.0+4.2	2.29	2.29	4.81	-	2.96	9.40	10.71	0.48	2.30	2.80	2.30	10.60	12.83	95
	2.0+2.0+5.0	2.13	2.13	5.33	-	3.10	9.60	10.90	0.50	2.25	2.72	2.40	10.40	12.47	95
	2.0+2.0+6.0	1.92	1.92	5.76	-	3.42	9.60	11.18	0.56	2.24	2.82	2.60	10.30	12.93	95
	2.0+2.0+7.1	1.73	1.73	6.14	-	3.74	9.60	11.18	0.62	2.23	2.81	2.90	10.30	12.87	95
	2.0+2.5+2.5	2.43	3.04	3.04	-	2.64	8.50	10.55	0.43	2.00	2.79	2.00	9.20	12.76	95
	2.0+2.5+3.5	2.33	2.91	4.07	-	2.80	9.30	10.69	0.46	2.32	2.85	2.20	10.60	13.03	95
	2.0+2.5+4.2	2.21	2.76	4.63	-	3.12	9.60	10.78	0.51	2.38	2.81	2.40	11.00	12.90	95
	2.0+2.5+5.0	2.02	2.53	5.05	-	3.26	9.60	11.10	0.53	2.25	2.79	2.50	10.30	12.80	95
	2.0+2.5+6.0	1.83	2.29	5.49	-	3.58	9.60	11.18	0.59	2.24	2.82	2.80	10.30	12.89	95
	2.0+2.5+7.1	1.66	2.07	5.88	-	3.90	9.60	11.18	0.65	2.23	2.80	3.00	10.20	12.82	95
	2.0+3.5+3.5	2.13	3.73	3.73	-	3.13	9.60	10.82	0.52	2.43	2.91	2.40	11.20	13.31	95
	2.0+3.5+4.2	1.98	3.46	4.16	-	3.28	9.60	10.85	0.54	2.38	2.83	2.60	11.00	12.95	95
	2.0+3.5+5.0	1.83	3.20	4.57	-	3.58	9.60	11.24	0.59	2.25	2.84	2.80	10.30	13.10	95
	2.0+3.5+6.0	1.67	2.92	5.01	-	3.90	9.60	11.24	0.65	2.24	2.83	3.00	10.30	13.00	95
	2.0+3.5+7.1	1.52	2.67	5.41	-	4.22	9.60	11.25	0.71	2.23	2.82	3.30	10.20	13.00	95
	2.0+4.2+4.2	1.85	3.88	3.88	-	3.60	9.60	10.80	0.60	2.34	2.76	2.80	10.70	12.70	95
	2.0+4.2+5.0	1.71	3.60	4.29	-	3.73	9.60	10.99	0.61	2.21	2.69	2.90	10.20	12.40	95
	2.0+4.2+6.0	1.57	3.30	4.72	-	4.05	9.60	11.26	0.67	2.20	2.78	3.20	10.10	12.80	95
	2.0+4.2+7.1	1.44	3.03	5.12	-	4.37	9.60	11.26	0.74	2.19	2.77	3.40	10.10	12.80	95
	2.0+5.0+5.0	1.60	4.00	4.00	-	4.04	9.60	11.09	0.66	2.12	2.61	3.10	9.70	11.96	95
	2.0+5.0+6.0	1.48	3.69	4.43	-	4.19	9.60	11.29	0.69	2.11	2.67	3.20	9.70	12.30	95
	2.0+5.0+7.1	1.36	3.40	4.83	-	4.51	9.60	11.37	0.75	2.10	2.70	3.50	9.70	12.35	95
	2.0+6.0+6.0	1.37	4.11	4.11	-	4.51	9.60	11.50	0.75	2.11	2.75	3.50	9.70	12.60	95
	2.5+2.5+2.5	3.20	3.20	3.20	-	2.80	9.60	10.69	0.46	2.42	2.84	2.20	11.10	12.98	95
	2.5+2.5+3.5	2.82	2.82	3.95	-	2.97	9.60	10.96	0.49	2.42	2.96	2.30	11.10	13.53	95
	2.5+2.5+4.2	2.61	2.61	4.38	-	3.28	9.60	11.04	0.54	2.37	2.92	2.60	10.90	13.40	95
	2.5+2.5+5.0	2.40	2.40	4.80	-	3.42	9.60	11.11	0.56	2.24	2.78	2.60	10.30	12.80	95
	2.5+2.5+6.0	2.18	2.18	5.24	-	3.74	9.60	11.24	0.62	2.23	2.82	2.90	10.30	13.00	95
	2.5+2.5+7.1	1.98	1.98	5.63	-	4.06	9.60	11.25	0.68	2.22	2.81	3.20	10.20	12.90	95
	2.5+3.5+3.5	2.53	3.54	3.54	-	3.29	9.60	11.15	0.55	2.42	3.03	2.60	11.10	14.00	95
	2.5+3.5+4.2	2.35	3.29	3.95	-	3.44	9.60	11.19	0.57	2.37	2.95	2.70	10.90	13.52	95
	2.5+3.5+5.0	2.18	3.05	4.36	-	3.74	9.60	11.21	0.62	2.24	2.80	2.90	10.30	12.83	95
	2.5+3.5+6.0	2.00	2.80	4.80	-	3.90	9.60	11.24	0.65	2.23	2.82	3.00	10.30	13.00	95
	2.5+3.5+7.1	1.83	2.56	5.20	-	4.22	9.60	11.25	0.71	2.22	2.81	3.30	10.20	12.90	95
	2.5+4.2+4.2	2.20	3.70	3.70	-	3.76	9.60	11.07	0.63	2.33	2.86	2.90	10.70	13.20	95
	2.5+4.2+5.0	2.05	3.45	4.10	-	3.89	9.60	11.12	0.64	2.20	2.73	3.00	10.10	12.60	95
	2.5+4.2+6.0	1.89	3.17	4.54	-	4.21	9.60	11.26	0.70	2.19	2.77	3.30	10.10	12.80	95
	2.5+4.2+7.1	1.74	2.92	4.94	-	4.53	9.60	11.27	0.77	2.18	2.76	3.60	10.00	12.70	95
	2.5+5.0+5.0	1.92	3.84	3.84	-	4.20	9.60	11.09	0.69	2.11	2.61	3.20	9.70	11.92	95
	2.5+5.0+6.0	1.78	3.56	4.27	-	4.35	9.60	11.29	0.72	2.11	2.66	3.30	9.70	12.30	95
	2.5+6.0+6.0	1.66	3.97	3.97	-	4.67	9.60	11.51	0.78	2.10	2.75	3.60	9.70	12.57	95
	3.5+3.5+3.5	3.20	3.20	3.20	-	3.61	9.60	11.15	0.61	2.42	3.03	2.90	11.10	14.00	95
	3.5+3.5+4.2	3.00	3.00	3.60	-	3.76	9.60	11.17	0.64	2.37	2.98	3.00	10.90	13.70	95
	3.5+3.5+5.0	2.80	2.80	4.00	-	3.90	9.60	11.21	0.65	2.24	2.80	3.00	10.30	12.83	95
	3.5+3.5+6.0	2.58	2.58	4.43	-	4.22	9.60	11.24	0.71	2.23	2.82	3.30	10.30	13.00	95
	3.5+3.5+7.1	2.38	2.38	4.83	-	4.54	9.60	11.25	0.77	2.22	2.81	3.60	10.20	12.90	95
	3.5+4.2+4.2	2.82	3.39	3.39	-	3.92	9.60	10.81	0.66	2.33	2.75	3.10	10.70	12.60	95
	3.5+4.2+5.0	2.65	3.17	3.78	-	4.21	9.60	10.99	0.71	2.20	2.68	3.30	10.10	12.30	95
3.5+4.2+6.0	2.45	2.94	4.20	-	4.37	9.60	11.26	0.74	2.19	2.77	3.40	10.10	12.80	95	
3.5+5.0+5.0	2.49	3.56	3.56	-	4.35	9.60	11.09	0.72	2.11	2.61	3.30	9.70	11.92	95	
3.5+5.0+6.0	2.32	3.31	3.97	-	4.67	9.60	11.37	0.78	2.11	2.70	3.60	9.70	12.36	95	
4.2+4.2+4.2	3.20	3.20	3.20	-	4.23	9.60	10.83	0.72	2.29	2.70	3.30	10.50	12.40	95	
4.2+4.2+5.0	3.01	3.01	3.58	-	4.37	9.60	11.00	0.73	2.17	2.63	3.40	10.00	12.10	95	
4.2+4.2+6.0	2.80	2.80	4.00	-	4.68	9.60	11.28	0.79	2.16	2.73	3.70	9.90	12.60	95	
4.2+5.0+5.0	2.84	3.38	3.38	-	4.67	9.60	11.10	0.77	2.09	2.57	3.60	9.60	11.76	95	
1.5+1.5+1.5+1.5	1.83	1.83	1.83	1.83	2.23	7.30	10.10	0.39	1.46	2.30	1.76	6.70	10.54	95	
1.5+1.5+1.5+2.0	1.85	1.85	1.85	2.46	2.38	8.00	10.32	0.39	1.64	2.36	1.81	7.60	10.90	95	
1.5+1.5+1.5+2.5	1.82	1.82	1.82	3.04	2.58	8.50	10.39	0.41	1.80	2.39	2.00	8.30	10.94	95	
1.5+1.5+1.5+3.5	1.74	1.74	1.74	4.07	2.91	9.30	10.60	0.46	2.05	2.46	2.20	9.40	11.30	95	
1.5+1.5+1.5+4.2	1.66	1.66	1.66	4.63	3.06	9.60	11.23	0.49	2.12	2.67	2.30	9.70	12.20	95	
1.5+1.5+1.5+5.0	1.52	1.52	1.52	5.05	3.37	9.60	11.30	0.53	2.05	2.59	2.50	9.40	11.90	95	
1.5+1.5+1.5+6.0	1.37	1.37	1.37	5.49	3.53	9.60	11.51	0.56	2.04	2.67	2.70	9.40	12.21	95	
1.5+1.5+1.5+7.1	1.24	1.24	1.24	5.88	3.85	9.60	11.57	0.62	2.04	2.67	2.90	9.40	12.30	95	
1.5+1.5+2.0+2.0	1.82	1.82	2.43	2.43	2.58	8.50	10.53	0.41	1.80	2.44	2.00	8.30	11.18	95	
1.5+1.5+2.0+2.5	1.80	1.80	2.40	3.00	2.74	9.00	10.60	0.44	1.95	2.45	2.10	9.00	11.30	95	
1.5+1.5+2.0+3.5	1.69	1.69	2.26	3.95	3.07	9.60	10.67	0.49	2.14	2.49	2.30	9.90	11.38	95	
1.5+1.5+2.0+4.2	1.57	1.57	2.09	4.38	3.23	9.60	11.23	0.51	2.11	2.66	2.40	9.70	12.16	95	
1.5+1.5+2.0+5.0	1.44	1.44	1.92	4.80	3.37	9.60	11.30	0.53	2.05	2.58	2.50	9.40	11.90	95	
1.5+1.5+2.0+6.0	1.31	1.31	1.75	5.24	3.69	9.60	11.51	0.59	2.04	2.66	2.80	9.40	12.18	95	
1.5+1.5+2.0+7.1	1.19	1.19	1.59	5.63	4.01	9.60	11.57	0.64	2.03	2.67	3.00	9.40	12.30	95	
1.5+1.5+2.5+2.5	1.80	1.80	3.00	3.00	2.90	9.60	10.60	0.46	2.14	2.44	2.20	9.80	11.30	95	
1.5+1.5+2.5+3.5	1.60	1.60	2.67	3.73	3.23	9.60	11.22	0.52	2.14	2.69	2.40	9.80	12.31	95	
1.5+1.5+2.5+4.2	1.48	1.48	2.47	4.16	3.39	9.60	11.23	0.54	2.11	2.65	2.60	9.70	12.13	95	
1.5+1.5+2.5+5.0	1.37	1.37	2.29	4.57	3.53	9.60	11.30	0.56	2.04	2.58	2.60	9.40	11.90	95	
1.5+1.5+2.5+6.0	1.25	1.25	2.09	5.01	3.85	9.60	11.51	0.61	2.04	2.66	2.90	9.40	12.15	95	
1.5+1.5+2.5+7.1	1.14	1.14	1.90	5.41	4.17	9.60	11.57	0.67	2.03	2.66	3.20	9.30	12.30	95	