

Heating 50Hz 230V-

①	②	Indoor air temperature [°C DB]											
		16°C			18°C			20°C			21°C		
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2.0+2.5+2.5+3.5+3.5	-20.0	5.38	1.89	5.24	1.91	5.09	1.94	5.01	1.95	4.91	1.96	4.77	1.98
	-15.0	6.65	2.00	6.50	2.02	6.35	2.05	6.27	2.06	6.19	2.08	6.03	2.10
	-10.0	7.92	2.12	7.76	2.14	7.61	2.16	7.53	2.17	7.46	2.19	7.30	2.21
	-5.0	9.18	2.23	9.03	2.25	8.87	2.28	8.80	2.29	8.72	2.30	8.57	2.32
	0.0	10.44	2.34	10.29	2.36	10.14	2.39	10.06	2.40	9.98	2.41	9.83	2.44
	6.0	11.97	2.48	11.81	2.50	11.66	2.52	11.57	2.53	11.50	2.55	11.34	2.57
	10.0	12.98	2.56	12.83	2.59	12.66	2.62	12.59	2.63	12.51	2.64	12.36	2.67
	15.0	14.24	2.68	14.09	2.70	13.94	2.72	13.86	2.74	13.77	2.75	13.62	2.78
	-20.0	5.39	1.88	5.25	1.90	5.10	1.93	5.02	1.94	4.93	1.96	4.78	1.98
	-15.0	6.66	2.00	6.51	2.01	6.36	2.04	6.28	2.05	6.20	2.07	6.05	2.09
2.0+2.5+2.5+3.5+4.2	-10.0	7.93	2.11	7.77	2.13	7.62	2.16	7.54	2.17	7.47	2.18	7.31	2.20
	-5.0	9.20	2.22	9.05	2.24	8.88	2.27	8.81	2.28	8.73	2.29	8.58	2.32
	0.0	10.46	2.34	10.31	2.35	10.16	2.38	10.07	2.39	9.99	2.40	9.84	2.43
	6.0	11.98	2.47	11.82	2.49	11.67	2.52	11.59	2.52	11.52	2.54	11.36	2.56
	10.0	12.99	2.55	12.84	2.58	12.68	2.61	12.61	2.62	12.53	2.63	12.38	2.66
	15.0	14.25	2.67	14.10	2.69	13.95	2.71	13.87	2.73	13.79	2.74	13.64	2.77
	-20.0	5.41	1.89	5.25	1.91	5.10	1.94	5.02	1.95	4.94	1.97	4.78	1.99
	-15.0	6.69	2.01	6.53	2.02	6.37	2.05	6.30	2.06	6.21	2.08	6.05	2.10
	-10.0	7.96	2.12	7.80	2.14	7.64	2.17	7.57	2.18	7.49	2.20	7.33	2.21
	-5.0	9.23	2.23	9.07	2.25	8.92	2.28	8.84	2.29	8.76	2.30	8.60	2.33
2.0+2.5+2.5+3.5+5.0	0.0	10.50	2.35	10.34	2.37	10.19	2.39	10.11	2.40	10.03	2.41	9.87	2.44
	6.0	12.02	2.48	11.87	2.50	11.71	2.53	11.63	2.54	11.55	2.56	11.40	2.58
	10.0	13.04	2.57	12.88	2.59	12.73	2.62	12.65	2.63	12.57	2.64	12.42	2.67
	15.0	14.31	2.68	14.15	2.71	14.00	2.73	13.92	2.75	13.84	2.76	13.69	2.78
	-20.0	5.36	1.88	5.21	1.89	5.07	1.92	4.98	1.93	4.90	1.95	4.76	1.97
	-15.0	6.64	1.99	6.49	2.01	6.34	2.03	6.26	2.04	6.18	2.06	6.02	2.08
	-10.0	7.91	2.10	7.75	2.12	7.59	2.14	7.51	2.15	7.44	2.17	7.28	2.19
	-5.0	9.16	2.21	9.01	2.23	8.85	2.26	8.78	2.26	8.70	2.27	8.55	2.30
	0.0	10.41	2.32	10.26	2.34	10.11	2.37	10.03	2.38	9.95	2.39	9.80	2.41
	6.0	11.93	2.45	11.77	2.47	11.62	2.50	11.54	2.51	11.47	2.52	11.31	2.54
2.0+2.5+3.5+3.5+3.5	10.0	12.93	2.53	12.78	2.56	12.62	2.59	12.55	2.60	12.47	2.61	12.32	2.63
	15.0	14.19	2.64	14.04	2.67	13.89	2.69	13.81	2.71	13.72	2.72	13.57	2.75
	-20.0	5.37	1.89	5.22	1.91	5.08	1.94	4.99	1.95	4.91	1.96	4.77	1.98
	-15.0	6.64	2.00	6.49	2.02	6.34	2.05	6.26	2.06	6.18	2.08	6.03	2.10
	-10.0	7.91	2.12	7.76	2.14	7.60	2.16	7.53	2.17	7.45	2.19	7.29	2.21
	-5.0	9.18	2.23	9.02	2.25	8.87	2.28	8.79	2.29	8.71	2.30	8.56	2.32
	0.0	10.45	2.34	10.29	2.36	10.13	2.39	10.06	2.40	9.98	2.41	9.83	2.44
	6.0	11.97	2.48	11.81	2.50	11.66	2.52	11.58	2.53	11.50	2.55	11.34	2.57
	10.0	12.98	2.56	12.83	2.59	12.66	2.62	12.59	2.63	12.51	2.64	12.36	2.67
	15.0	14.25	2.68	14.09	2.70	13.93	2.72	13.85	2.74	13.78	2.75	13.62	2.78
2.5+2.5+2.5+2.5+2.5	-20.0	5.37	1.89	5.22	1.90	5.08	1.93	4.98	1.94	4.91	1.96	4.77	1.98
	-15.0	6.64	2.00	6.49	2.02	6.34	2.05	6.26	2.06	6.18	2.08	6.03	2.09
	-10.0	7.92	2.11	7.75	2.13	7.60	2.16	7.52	2.17	7.45	2.19	7.29	2.21
	-5.0	9.18	2.23	9.03	2.25	8.87	2.27	8.80	2.28	8.71	2.29	8.56	2.32
	0.0	10.44	2.34	10.29	2.36	10.14	2.39	10.06	2.40	9.98	2.41	9.82	2.44
	6.0	11.97	2.47	11.80	2.49	11.65	2.52	11.57	2.53	11.50	2.55	11.34	2.57
	10.0	12.98	2.56	12.82	2.59	12.66	2.62	12.59	2.63	12.51	2.63	12.36	2.66
	15.0	14.24	2.67	14.09	2.70	13.93	2.72	13.85	2.74	13.77	2.75	13.62	2.78
	-20.0	5.39	1.89	5.22	1.90	5.06	1.93	4.98	1.94	4.92	1.96	4.75	1.98
	-15.0	6.65	2.00	6.49	2.02	6.34	2.05	6.26	2.06	6.18	2.08	6.02	2.09
2.5+2.5+2.5+2.5+3.5	-10.0	7.91	2.11	7.76	2.13	7.61	2.16	7.53	2.17	7.45	2.19	7.29	2.21
	-5.0	9.18	2.23	9.02	2.25	8.87	2.27	8.79	2.28	8.72	2.29	8.56	2.32
	0.0	10.44	2.34	10.29	2.36	10.13	2.39	10.06	2.40	9.98	2.41	9.83	2.44
	6.0	11.97	2.47	11.80	2.49	11.65	2.52	11.57	2.53	11.50	2.55	11.34	2.57
	10.0	12.97	2.56	12.82	2.59	12.66	2.62	12.59	2.63	12.51	2.63	12.36	2.66
	15.0	14.24	2.67	14.08	2.70	13.93	2.72	13.85	2.74	13.77	2.75	13.62	2.78
	-20.0	5.39	1.88	5.25	1.90	5.10	1.93	5.02	1.94	4.93	1.96	4.78	1.99
	-15.0	6.68	2.01	6.52	2.03	6.37	2.05	6.29	2.06	6.21	2.07	6.06	2.10
	-10.0	7.95	2.12	7.79	2.14	7.64	2.17	7.56	2.18	7.48	2.19	7.33	2.21
	-5.0	9.22	2.23	9.06	2.25	8.91	2.28	8.83	2.29	8.75	2.30	8.60	2.33

①	②	Indoor air temperature [°C DB]											
		16°C			18°C			20°C			21°C		
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2.5+2.5+2.5+2.5+4.2	-20.0	5.39	1.88	5.22	1.90	5.07	1.93	4.99	1.94	4.93	1.95	4.75	1.97
	-15.0	6.65	1.99	6.49	2.01	6.34	2.04	6.26	2.05	6.19	2.07	6.03	2.09
	-10.0	7.91	2.11	7.76	2.12	7.61	2.15	7.53	2.16	7.45	2.18	7.30	2.20
	-5.0	9.19	2.22	9.03	2.24	8.87	2.27	8.79	2.28	8.72	2.28	8.56	2.31
	0.0	10.45	2.33	10.30	2.35	10.14	2.38	10.06	2.39	9.98	2.40	9.83	2.43
	6.0	11.97	2.46	11.81	2.48	11.66	2.51	11.58	2.52	11.51	2.54	11.35	2.56
	10.0	12.98	2.55	12.83	2.58	12.67	2.61	12.60	2.62	12.52	2.62	12.37	2.65
	15.0	14.24	2.66	14.09	2.69	13.94	2.71	13.86	2.73	13.78	2.74	13.63	2.77
	-20.0	5.41	1.89	5.25	1.91	5.10	1.94	5.02	1.95	4.94	1.95	4.79	1.99
	-15.0	6.68	2.01	6.52	2.03	6.37	2.05	6.29	2.06	6.21	2.07	6.06	2.10
2.5+2.5+2.5+2.5+5.0	-10.0	7.95	2.12	7.79	2.14	7.64	2.17	7.56	2.18	7.48	2.19	7.33	2.21
	-5.0	9.22	2.23	9.06	2.25	8.91	2.28	8.83	2.29	8.75	2.30	8.60	2.33
	0.0	10.49	2.34	10.33	2.37	10.18	2.39	10.10	2.40	10.02	2.41	9.87	2.44
	6.0	12.01	2.48	11.86	2.50	11.70	2.53	11.62	2.54	11.54	2.56	11.39	2.57
	10.0	13.04	2.56	12.87	2.59	12.72	2.62	12.64	2.63	12.56	2.64	12.40	2.67
	15.0	14.30	2.68	14.15	2.71	13.99	2.73	13.92	2.74	13.84	2.75	13.68	2.78
	-20.0	5.38	1.89	5.24	1.90	5.08	1.93	5.00	1.94	4.91	1.95	4.77	1.98
	-15.0	6.65	2.00	6.50	2.02	6.35	2.05	6.27	2.06	6.18	2.07	6.03	2.09
	-10.0	7.92	2.11	7.76	2.13	7.61	2.16	7.53	2.17	7.46	2.18	7.29	2.21
	-5.0	9.18	2.23	9.03	2.25	8.87	2.27	8.80	2.28	8.72	2.29	8.57	2.32
2.5+2.5+2.5+3.5+3.5	0.0	10.44	2.33	10.29	2.36	10.14	2.39	10.06	2.40	9.98	2.41	9.83	2.44
	6.0	11.97	2.47	11.80	2.49	11.65	2.52	11.57	2.53	11.50	2.55	11.34	2.57
	10.0	12.97	2.56	12.82	2.59	12.66	2.62	12.59	2.63	12.51	2.63	12.36	2.66
	15.0	14.24	2.67	14.08	2.70	13.93	2.72	13.85	2.74	13.77	2.75	13.62	2.78