

①	②	Indoor air temperature [°C DB]											
		16°C		18°C		20°C		21°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2,5	-15,0	2,03	1,11	1,98	1,12	1,93	1,13	1,89	1,14	1,87	1,14	1,82	1,14
	-10,0	2,45	1,15	2,40	1,16	2,35	1,17	2,32	1,18	2,29	1,18	2,24	1,19
	-5,0	3,03	1,22	2,98	1,23	2,93	1,24	2,90	1,24	2,88	1,25	2,83	1,25
	0,0	3,62	1,28	3,57	1,29	3,52	1,30	3,49	1,30	3,46	1,31	3,41	1,32
	6,0	4,20	1,34	4,15	1,35	4,10	1,36	4,07	1,36	4,05	1,37	4,00	1,38
	10,0	4,54	1,38	4,49	1,39	4,43	1,40	4,41	1,40	4,38	1,41	4,33	1,42
	15,0	4,95	1,42	4,90	1,43	4,85	1,44	4,83	1,44	4,80	1,45	4,75	1,46
3,5	-15,0	2,07	1,21	2,02	1,22	1,97	1,24	1,93	1,24	1,91	1,25	1,86	1,27
	-10,0	2,55	1,27	2,48	1,28	2,42	1,30	2,39	1,30	2,35	1,31	2,29	1,32
	-5,0	3,27	1,36	3,21	1,37	3,15	1,38	3,11	1,39	3,08	1,39	3,02	1,41
	0,0	4,00	1,44	3,94	1,45	3,87	1,47	3,84	1,47	3,81	1,48	3,75	1,49
	6,0	4,73	1,52	4,66	1,54	4,60	1,55	4,58	1,56	4,54	1,56	4,47	1,58
	10,0	5,14	1,57	5,08	1,58	5,02	1,60	4,98	1,60	4,95	1,61	4,89	1,62
	15,0	5,66	1,63	5,60	1,65	5,53	1,66	5,50	1,66	5,47	1,67	5,38	1,67
2,5+2,5	-15,0	2,60	1,24	2,53	1,25	2,45	1,26	2,41	1,27	2,37	1,28	2,29	1,29
	-10,0	3,25	1,30	3,18	1,32	3,10	1,33	3,06	1,33	3,02	1,34	2,94	1,35
	-5,0	4,16	1,38	4,08	1,40	4,00	1,41	3,96	1,41	3,92	1,42	3,84	1,43
	0,0	5,06	1,46	4,98	1,48	4,90	1,49	4,86	1,50	4,82	1,50	4,74	1,51
	6,0	5,96	1,54	5,88	1,56	5,80	1,57	5,76	1,58	5,72	1,58	5,64	1,60
	10,0	6,47	1,59	6,39	1,60	6,31	1,62	6,28	1,62	6,24	1,63	6,16	1,64
	15,0	7,12	1,65	7,04	1,66	6,96	1,67	6,92	1,68	6,88	1,69	6,80	1,70
2,5+3,5	-15,0	2,69	1,28	2,61	1,29	2,53	1,30	2,49	1,31	2,45	1,32	2,36	1,33
	-10,0	3,36	1,34	3,28	1,36	3,20	1,37	3,16	1,38	3,12	1,38	3,04	1,39
	-5,0	4,30	1,42	4,22	1,44	4,13	1,45	4,09	1,46	4,05	1,46	3,97	1,47
	0,0	5,23	1,50	5,15	1,52	5,07	1,53	5,03	1,54	4,99	1,54	4,90	1,55
	6,0	6,16	1,58	6,08	1,60	6,00	1,61	5,96	1,62	5,92	1,62	5,84	1,64
	10,0	6,70	1,63	6,61	1,64	6,53	1,66	6,49	1,66	6,45	1,67	6,37	1,68
	15,0	7,36	1,69	7,28	1,70	7,20	1,71	7,16	1,72	7,12	1,73	7,04	1,74
3,5+3,5	-15,0	2,68	1,29	2,60	1,30	2,51	1,32	2,46	1,32	2,42	1,33	2,34	1,34
	-10,0	3,38	1,35	3,29	1,36	3,21	1,38	3,16	1,38	3,12	1,39	3,04	1,40
	-5,0	4,34	1,44	4,26	1,45	4,17	1,46	4,13	1,47	4,09	1,47	4,00	1,49
	0,0	5,30	1,52	5,22	1,53	5,14	1,55	5,09	1,55	5,05	1,56	4,97	1,57
	6,0	6,27	1,60	6,18	1,62	6,10	1,63	6,06	1,64	6,02	1,64	5,93	1,66
	10,0	6,82	1,65	6,74	1,66	6,65	1,68	6,61	1,68	6,57	1,69	6,48	1,70
	15,0	7,51	1,71	7,42	1,73	7,34	1,74	7,30	1,74	7,26	1,75	7,17	1,76

Symbols

TC: Total capacity [kW]

PI: Power input [kW]

①: Indoor unit combinations

②: Outdoor air temperature [°C DB]

Notes

1. The capacities are based on the following conditions:

Corresponding refrigerant piping length: ·5· m

Level difference: ·0· m

2. The bold cells indicate the standard conditions.

3. The values above are for connecting with the following indoor unit types:

·2.5, 3.5· kW class

Wall mounted

ATXF-A

4. The heating capacity does not include the capacity drop that occurs during a frosting period and defrost operation.