

2AMXF50B

(50Hz 230V calefacción)

①	②	Temperatura de aire interior [°C DB]											
		16°C		18°C		20°C		21°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2.5	-15.0	2.45	1.03	2.34	1.04	2.29	1.05	2.27	1.06	2.24	1.06	2.19	1.07
	-11.0	2.67	1.05	2.61	1.06	2.56	1.07	2.54	1.07	2.51	1.08	2.46	1.09
	-6.0	3.28	1.09	3.13	1.10	3.08	1.11	3.06	1.11	3.03	1.12	2.98	1.13
	0.0	3.70	1.14	3.65	1.15	3.60	1.16	3.57	1.16	3.55	1.17	3.50	1.17
	6.0	4.20	1.19	4.15	1.20	4.10	1.19	4.07	1.21	4.05	1.22	4.00	1.23
	10.0	4.54	1.23	4.49	1.24	4.43	1.25	4.41	1.25	4.38	1.26	4.33	1.27
	15.0	4.95	1.27	4.90	1.28	4.85	1.29	4.83	1.29	4.80	1.30	4.75	1.31
3.5	-15.0	2.64	1.13	2.58	1.14	2.53	1.15	2.50	1.16	2.47	1.17	2.42	1.18
	-11.0	2.93	1.14	2.87	1.15	2.81	1.16	2.78	1.17	2.75	1.18	2.69	1.19
	-6.0	3.43	1.19	3.37	1.20	3.31	1.21	3.28	1.22	3.25	1.22	3.19	1.24
	0.0	4.00	1.27	3.94	1.28	3.87	1.30	3.84	1.30	3.81	1.31	3.75	1.32
	6.0	4.73	1.35	4.66	1.37	4.60	1.36	4.58	1.39	4.54	1.39	4.47	1.41
	10.0	5.14	1.40	5.08	1.41	5.02	1.43	4.98	1.43	4.95	1.44	4.89	1.45
	15.0	5.66	1.46	5.60	1.48	5.53	1.49	5.50	1.49	5.47	1.50	5.38	1.50
4.2	-15.0	2.50	1.03	2.43	1.04	2.35	1.05	2.31	1.06	2.27	1.07	2.19	1.08
	-11.0	3.15	1.09	3.08	1.11	3.00	1.12	2.96	1.12	2.92	1.13	2.84	1.14
	-6.0	4.06	1.17	3.98	1.19	3.90	1.20	3.86	1.20	3.82	1.21	3.74	1.22
	0.0	4.96	1.25	4.88	1.27	4.80	1.28	4.76	1.29	4.72	1.29	4.64	1.30
	6.0	5.86	1.33	5.78	1.35	5.70	1.36	5.66	1.37	5.62	1.37	5.54	1.39
	10.0	6.37	1.38	6.29	1.39	6.21	1.41	6.18	1.41	6.14	1.42	6.06	1.43
	15.0	7.02	1.44	6.94	1.45	6.86	1.46	6.82	1.47	6.78	1.48	6.70	1.49
2.5+2.5	-15.0	2.85	1.08	2.76	1.09	2.74	1.10	2.65	1.11	2.62	1.12	2.55	1.13
	-11.0	3.50	1.14	3.38	1.16	3.32	1.17	3.26	1.17	3.22	1.18	3.14	1.19
	-6.0	4.43	1.22	4.28	1.24	4.20	1.25	4.16	1.25	4.12	1.26	4.04	1.27
	0.0	5.34	1.30	5.18	1.32	5.10	1.33	5.06	1.34	5.02	1.34	4.94	1.35
	6.0	6.26	1.38	6.08	1.40	6.00	1.41	5.96	1.42	5.92	1.42	5.84	1.44
	10.0	6.78	1.43	6.59	1.44	6.51	1.46	6.48	1.46	6.44	1.47	6.36	1.48
	15.0	7.44	1.49	7.24	1.50	7.16	1.51	7.12	1.52	7.08	1.53	7.00	1.54

①	②	Temperatura de aire interior [°C DB]											
		16°C		18°C		20°C		21°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	
2.5+3.5	-15.0	2.71	1.11	2.70	1.12	2.63	1.13	2.60	1.14	2.57	1.15	2.50	1.16
	-11.0	3.36	1.19	3.28	1.21	3.20	1.22	3.16	1.23	3.12	1.23	3.04	1.24
	-6.0	4.30	1.27	4.22	1.29	4.13	1.30	4.09	1.31	4.05	1.31	3.97	1.32
	0.0	5.23	1.35	5.15	1.37	5.07	1.38	5.03	1.39	4.99	1.39	4.90	1.40
	6.0	6.16	1.43	6.08	1.45	6.00	1.43	5.96	1.47	5.92	1.47	5.84	1.49
	10.0	6.70	1.48	6.61	1.49	6.53	1.51	6.49	1.51	6.45	1.52	6.37	1.53
	15.0	7.36	1.54	7.28	1.55	7.20	1.56	7.16	1.57	7.12	1.58	7.04	1.58
2.5+4.2	-15.0	2.58	1.09	2.50	1.10	2.41	1.12	2.36	1.12	2.32	1.13	2.24	1.14
	-11.0	3.28	1.15	3.19	1.16	3.11	1.18	3.06	1.18	3.02	1.19	2.94	1.20
	-6.0	4.24	1.24	4.16	1.25	4.07	1.26	4.03	1.27	3.99	1.27	3.90	1.29
	0.0	5.20	1.32	5.12	1.33	5.04	1.35	4.99	1.35	4.95	1.36	4.87	1.37
	6.0	6.17	1.40	6.08	1.42	6.00	1.43	5.96	1.44	5.92	1.44	5.83	1.46
	10.0	6.72	1.45	6.64	1.46	6.55	1.48	6.51	1.48	6.47	1.49	6.38	1.50
	15.0	7.41	1.51	7.32	1.53	7.24	1.54	7.20	1.54	7.16	1.55	7.07	1.56
3.5+3.5	-15.0	2.68	1.09	2.60	1.10	2.51	1.12	2.46	1.12	2.42	1.13	2.34	1.14
	-11.0	3.38	1.15	3.29	1.16	3.21	1.18	3.16	1.18	3.12	1.19	3.04	1.20
	-6.0	4.34	1.24	4.26	1.25	4.17	1.26	4.13	1.27	4.09	1.27	4.00	1.29
	0.0	5.30	1.32	5.22	1.33	5.14	1.35	5.09	1.35	5.05	1.36	4.97	1.37
	6.0	6.27	1.40	6.18	1.42	6.10	1.43	6.06	1.44	6.02	1.44	5.93	1.46
	10.0	6.82	1.45	6.74	1.46	6.65	1.48	6.61	1.48	6.57	1.49	6.48	1.50
	15.0	7.51	1.51	7.42	1.53	7.34	1.54	7.30	1.54	7.26	1.55	7.17	1.56