

①	②	Indoor air temperature [°C WB]											
		14°C		16°C		18°C		19°C		22°C		24°C	
		TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW
1.5	22.0	2.19	0.44	2.55	0.51	2.68	0.52	2.74	0.53	2.94	0.55	3.07	0.56
	25.0	2.19	0.48	2.47	0.53	2.60	0.54	2.66	0.55	2.86	0.57	2.99	0.58
	32.0	2.15	0.58	2.28	0.59	2.41	0.60	2.48	0.61	2.68	0.62	2.81	0.63
	35.0	2.07	0.60	2.20	0.61	2.33	0.62	2.40	0.63	2.60	0.65	2.73	0.66
	40.0	1.94	0.65	2.07	0.66	2.20	0.67	2.27	0.68	2.46	0.69	2.59	0.71
2.0	22.0	1.86	0.68	1.99	0.69	2.12	0.70	2.19	0.71	2.38	0.72	2.52	0.73
	25.0	1.78	0.71	1.91	0.72	2.04	0.73	2.11	0.74	2.31	0.75	2.44	0.76
	22.0	2.79	0.59	3.15	0.66	3.28	0.67	3.34	0.68	3.54	0.70	3.67	0.71
	25.0	2.79	0.63	3.07	0.68	3.20	0.69	3.26	0.70	3.46	0.72	3.59	0.73
	32.0	2.75	0.73	2.88	0.74	3.01	0.75	3.08	0.76	3.28	0.77	3.41	0.78
2.5	22.0	2.67	0.75	2.80	0.76	2.93	0.77	3.00	0.78	3.20	0.80	3.33	0.81
	25.0	2.54	0.80	2.67	0.81	2.80	0.82	2.87	0.83	3.06	0.84	3.19	0.86
	32.0	2.46	0.83	2.59	0.84	2.72	0.85	2.79	0.86	2.98	0.87	3.12	0.88
	35.0	2.38	0.86	2.51	0.87	2.64	0.88	2.71	0.89	2.91	0.90	3.04	0.91
	22.0	2.99	0.68	3.35	0.75	3.48	0.76	3.54	0.77	3.74	0.79	3.87	0.80
3.5	22.0	2.99	0.72	3.27	0.77	3.40	0.78	3.46	0.79	3.66	0.81	3.79	0.82
	25.0	2.95	0.82	3.08	0.83	3.21	0.84	3.28	0.85	3.48	0.86	3.61	0.87
	32.0	2.87	0.84	3.00	0.85	3.13	0.86	3.20	0.87	3.40	0.89	3.53	0.90
	35.0	2.74	0.89	2.87	0.90	3.00	0.91	3.07	0.92	3.26	0.93	3.39	0.95
	22.0	3.02	0.68	3.70	0.91	4.44	1.13	4.59	1.16	4.88	1.19	5.07	1.21
4.2	22.0	3.02	0.73	3.70	0.91	4.44	1.13	4.59	1.16	4.88	1.19	5.07	1.21
	25.0	3.02	0.86	3.70	1.08	4.22	1.25	4.32	1.26	4.61	1.29	4.80	1.31
	32.0	3.02	0.92	3.70	1.17	4.10	1.29	4.20	1.30	4.49	1.33	4.68	1.35
	35.0	3.02	1.05	3.70	1.34	3.91	1.37	4.01	1.38	4.29	1.41	4.49	1.43
	22.0	3.42	0.87	4.10	1.04	4.84	1.24	5.11	1.31	5.39	1.34	5.59	1.36
5.0	22.0	3.42	0.92	4.10	1.10	4.84	1.32	4.99	1.35	5.28	1.38	5.47	1.40
	25.0	3.42	1.05	4.10	1.27	4.62	1.44	4.72	1.45	5.01	1.48	5.20	1.50
	32.0	3.42	1.11	4.10	1.36	4.50	1.48	4.60	1.49	4.89	1.52	5.08	1.54
	35.0	3.42	1.24	4.10	1.53	4.31	1.56	4.41	1.57	4.69	1.60	4.89	1.62
	22.0	3.68	1.17	4.52	1.51	5.43	1.95	5.55	1.96	5.92	2.01	6.17	2.04

①	②	Indoor air temperature [°C WB]											
		14°C		16°C		18°C		19°C		22°C		24°C	
		TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW	TC kW	PI kW
1.5+1.5	22.0	4.00	0.68	5.01	1.01	5.28	1.04	5.42	1.06	5.83	1.10	6.11	1.13
	25.0	4.00	0.78	4.84	1.07	5.12	1.10	5.26	1.11	5.67	1.16	5.94	1.19
	32.0	4.00	1.08	4.45	1.21	4.73	1.24	4.87	1.26	5.28	1.30	5.55	1.33
	35.0	4.00	1.24	4.29	1.28	4.56	1.31	4.70	1.32	5.11	1.37	5.39	1.40
	40.0	3.74	1.36	4.01	1.39	4.29	1.42	4.42	1.44	4.83	1.49	5.11	1.52
1.5+2.0	22.0	4.00	0.66	5.01	0.99	5.28	1.02	5.42	1.04	5.83	1.08	6.11	1.11
	25.0	4.00	0.76	4.84	1.05	5.12	1.08	5.26	1.09	5.67	1.14	5.94	1.17
	32.0	4.00	1.06	4.45	1.19	4.73	1.22	4.87	1.24	5.28	1.28	5.55	1.31
	35.0	4.00	1.22	4.29	1.26	4.56	1.29	4.70	1.30	5.11	1.35	5.39	1.38
	40.0	3.74	1.34	4.01	1.37	4.29	1.40	4.42	1.42	4.83	1.47	5.11	1.50
1.5+2.5	22.0	4.00	0.66	5.01	0.99	5.28	1.02	5.42	1.04	5.83	1.08	6.11	1.11
	25.0	4.00	0.76	4.84	1.05	5.12	1.08	5.26	1.09	5.67	1.14	5.94	1.17
	32.0	4.00	1.06	4.45	1.19	4.73	1.22	4.87	1.24	5.28	1.28	5.55	1.31
	35.0	4.00	1.22	4.29	1.26	4.56	1.29	4.70	1.30	5.11	1.35	5.39	1.38
	40.0	3.74	1.34	4.01	1.37	4.29	1.40	4.42	1.42	4.83	1.47	5.11	1.50
1.5+3.5	22.0	4.00	0.66	5.01	0.99	5.28	1.02	5.42	1.04	5.83	1.08	6.11	1.11
	25.0	4.00	0.76	4.84	1.05	5.12	1.08	5.26	1.09	5.67	1.14	5.94	1.17
	32.0	4.00	1.06	4.45	1.19	4.73	1.22	4.87	1.24	5.28	1.28	5.55	1.31
	35.0	4.00	1.22	4.29	1.26	4.56	1.29	4.70	1.30	5.11	1.35	5.39	1.38
	40.0	3.74	1.34	4.01	1.37	4.29	1.40	4.42	1.42	4.83	1.47	5.11	1.50
1.5+4.2	22.0	4.00	0.66	5.01	0.99	5.28	1.02	5.42	1.04	5.83	1.08	6.11	1.11
	25.0	4.00	0.76	4.84	1.05	5.12	1.08	5.26	1.09	5.67	1.14	5.94	1.17
	32.0	4.00	1.06	4.45	1.19	4.73	1.22	4.87	1.24	5.28	1.28	5.55	1.31
	35.0	4.00	1.22	4.29	1.26	4.56	1.29	4.70	1.30	5.11	1.35	5.39	1.38
	40.0	3.74	1.34	4.01	1.37	4.29	1.40	4.42	1.42	4.83	1.47	5.11	1.50
1.5+5.0	22.0	4.00	0.66	5.01	0.99	5.28	1.02	5.42	1.04	5.83	1.08	6.11	1.11
	25.0	4.00	0.76	4.84	1.05	5.12	1.08	5.26	1.09	5.67	1.14	5.94	1.17
	32.0	4.00	1.06	4.45	1.19	4.73	1.22	4.87	1.24	5.28	1.28	5.55	1.31
	35.0	4.00	1.22	4.29	1.26	4.56	1.29	4.70	1.30	5.11	1.35	5.39	1.38
	40.0	3.74	1.34	4.01	1.37	4.29	1.40	4.42	1.42	4.83	1.47	5.11	1.50

Notes

- The capacities are based on the following conditions:
Corresponding refrigerant piping length: ·5-m
Level difference: ·0-m
- The bold cells indicate the standard conditios.
- The values above are for connecting with the following indoor unit types:
·1.5, 2.0, 2.5, 3.5, 4.2, 5.0 · kW class
Wall-mountend ·CTXM-M, FTXM-M· series
- Editable data for this drawing are available in ·GDE· system.

Symbols

- TC: Total capacity [kW]
PI: Power input [kW]
① Indoor unit combinations
② Outdoor air temperature
[° C DB]