

①	②	Indoor air temperature [°C WB]											
		14°C		16°C		18°C		19°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
4.2+4.2	22.0	6.10	1.63	6.83	1.88	7.13	1.91	7.27	1.93	7.72	1.98	8.01	2.02
	25.0	6.10	1.77	6.65	1.94	6.95	1.98	7.10	2.00	7.54	2.05	7.83	2.09
	32.0	5.94	2.07	6.24	2.11	6.53	2.15	6.68	2.16	7.12	2.22	7.42	2.25
	35.0	5.76	2.15	6.06	2.19	6.35	2.22	6.50	2.24	6.94	2.30	7.24	2.33
	40.0	5.46	2.29	5.76	2.33	6.05	2.36	6.20	2.38	6.64	2.43	6.94	2.47
	43.0	5.29	2.38	5.58	2.41	5.88	2.45	6.02	2.47	6.47	2.52	6.76	2.56
46.0	4.79	2.06	5.01	2.06	5.23	2.06	5.34	2.06	5.66	2.06	5.87	2.06	
1.5+1.5+1.5	22.0	6.74	1.90	7.07	1.93	7.39	1.96	7.55	1.98	8.04	2.03	8.36	2.07
	25.0	6.54	1.96	6.87	1.99	7.19	2.03	7.36	2.05	7.84	2.10	8.17	2.13
	32.0	6.09	2.12	6.41	2.16	6.73	2.19	6.90	2.21	7.38	2.26	7.71	2.29
	35.0	5.89	2.20	6.21	2.23	6.54	2.27	6.70	2.28	7.19	2.33	7.51	2.37
	40.0	5.56	2.33	5.89	2.36	6.21	2.40	6.37	2.41	6.86	2.47	7.18	2.50
	43.0	5.36	2.41	5.69	2.45	6.01	2.48	6.18	2.50	6.66	2.55	6.99	2.59
46.0	4.83	2.19	5.08	2.19	5.33	2.19	5.45	2.19	5.80	2.19	6.03	2.19	
1.5+1.5+2.0	22.0	6.74	1.88	7.07	1.91	7.39	1.94	7.55	1.96	8.04	2.01	8.36	2.05
	25.0	6.54	1.94	6.87	1.97	7.19	2.01	7.36	2.03	7.84	2.08	8.17	2.11
	32.0	6.09	2.10	6.41	2.14	6.73	2.17	6.90	2.19	7.38	2.24	7.71	2.27
	35.0	5.89	2.18	6.21	2.21	6.54	2.25	6.70	2.26	7.19	2.31	7.51	2.35
	40.0	5.56	2.31	5.89	2.34	6.21	2.38	6.37	2.39	6.86	2.45	7.18	2.48
	43.0	5.36	2.39	5.69	2.43	6.01	2.46	6.18	2.48	6.66	2.53	6.99	2.57
46.0	4.83	2.17	5.08	2.17	5.33	2.17	5.45	2.17	5.80	2.17	6.03	2.17	
1.5+1.5+2.5	22.0	6.74	1.85	7.07	1.88	7.39	1.91	7.55	1.93	8.04	1.98	8.36	2.02
	25.0	6.54	1.91	6.87	1.94	7.19	1.98	7.36	2.00	7.84	2.05	8.17	2.08
	32.0	6.09	2.07	6.41	2.11	6.73	2.14	6.90	2.16	7.38	2.21	7.71	2.24
	35.0	5.89	2.15	6.21	2.18	6.54	2.22	6.70	2.23	7.19	2.28	7.51	2.32
	40.0	5.56	2.28	5.89	2.31	6.21	2.35	6.37	2.36	6.86	2.42	7.18	2.45
	43.0	5.36	2.36	5.69	2.40	6.01	2.43	6.18	2.45	6.66	2.50	6.99	2.54
46.0	4.83	2.14	5.08	2.14	5.33	2.14	5.45	2.14	5.80	2.14	6.03	2.14	
1.5+1.5+3.5	22.0	6.84	1.90	7.17	1.93	7.49	1.96	7.65	1.98	8.14	2.03	8.47	2.07
	25.0	6.64	1.96	6.97	1.99	7.29	2.03	7.46	2.05	7.95	2.10	8.27	2.13
	32.0	6.18	2.12	6.51	2.16	6.83	2.19	7.00	2.21	7.49	2.26	7.81	2.29
	35.0	5.99	2.20	6.31	2.23	6.64	2.27	6.80	2.28	7.29	2.33	7.61	2.37
	40.0	5.66	2.33	5.98	2.36	6.31	2.40	6.47	2.41	6.96	2.47	7.28	2.50
	43.0	5.46	2.41	5.79	2.45	6.11	2.48	6.27	2.51	6.76	2.55	7.09	2.59
46.0	4.92	2.19	5.18	2.19	5.42	2.19	5.55	2.19	5.90	2.19	6.13	2.19	
1.5+1.5+4.2	22.0	6.84	1.88	7.17	1.91	7.49	1.94	7.65	1.96	8.14	2.01	8.47	2.05
	25.0	6.64	1.94	6.97	1.97	7.29	2.01	7.46	2.03	7.95	2.08	8.27	2.11
	32.0	6.18	2.10	6.51	2.14	6.83	2.17	7.00	2.19	7.49	2.24	7.81	2.27
	35.0	5.99	2.18	6.31	2.21	6.64	2.25	6.80	2.26	7.29	2.31	7.61	2.35
	40.0	5.66	2.31	5.98	2.34	6.31	2.38	6.47	2.39	6.96	2.45	7.28	2.48
	43.0	5.46	2.39	5.79	2.43	6.11	2.46	6.27	2.49	6.76	2.53	7.09	2.57
46.0	4.92	2.17	5.18	2.17	5.42	2.17	5.55	2.17	5.90	2.17	6.13	2.17	

①	②	Indoor air temperature [°C WB]											
		14°C		16°C		18°C		19°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
1.5+1.5+5+5.0	22.0	7.14	1.77	7.48	1.80	7.82	1.84	7.98	1.86	8.49	1.91	8.82	1.95
	25.0	6.94	1.83	7.28	1.87	7.61	1.91	7.78	1.92	8.28	1.98	8.62	2.01
	32.0	6.46	2.00	6.80	2.04	7.14	2.08	7.30	2.09	7.81	2.15	8.14	2.18
	35.0	6.26	2.08	6.60	2.12	6.93	2.15	7.10	2.17	7.60	2.23	7.94	2.26
	40.0	5.92	2.22	6.26	2.26	6.59	2.29	6.76	2.31	7.26	2.37	7.60	2.40
	43.0	5.72	2.31	6.05	2.34	6.39	2.38	6.56	2.40	7.06	2.45	7.40	2.49
46.0	5.07	1.98	5.32	1.98	5.56	1.98	5.68	1.98	6.04	1.98	6.27	1.98	
1.5+2.0+2.0	22.0	6.74	1.83	7.07	1.86	7.39	1.89	7.55	1.91	8.04	1.96	8.36	2.00
	25.0	6.54	1.89	6.87	1.92	7.19	1.96	7.36	1.98	7.84	2.03	8.17	2.06
	32.0	6.09	2.05	6.41	2.09	6.73	2.12	6.90	2.14	7.38	2.19	7.71	2.22
	35.0	5.89	2.13	6.21	2.16	6.54	2.20	6.70	2.21	7.19	2.26	7.51	2.30
	40.0	5.56	2.26	5.89	2.29	6.21	2.33	6.37	2.34	6.86	2.40	7.18	2.43
	43.0	5.36	2.34	5.69	2.38	6.01	2.41	6.18	2.43	6.66	2.48	6.99	2.52
46.0	4.83	2.12	5.08	2.12	5.33	2.12	5.45	2.12	5.80	2.12	6.03	2.12	
1.5+2.0+2.5	22.0	6.74	1.81	7.07	1.84	7.39	1.87	7.55	1.89	8.04	1.94	8.36	1.98
	25.0	6.54	1.87	6.87	1.90	7.19	1.94	7.36	1.96	7.84	2.01	8.17	2.04
	32.0	6.09	2.03	6.41	2.07	6.73	2.10	6.90	2.12	7.38	2.17	7.71	2.20
	35.0	5.89	2.11	6.21	2.14	6.54	2.18	6.70	2.19	7.19	2.24	7.51	2.28
	40.0	5.56	2.24	5.89	2.27	6.21	2.31	6.37	2.32	6.86	2.38	7.18	2.41
	43.0	5.36	2.32	5.69	2.36	6.01	2.39	6.18	2.41	6.66	2.46	6.99	2.50
46.0	4.83	2.10	5.08	2.10	5.33	2.10	5.45	2.10	5.80	2.10	6.03	2.10	
1.5+2.0+3+5	22.0	6.84	1.85	7.17	1.88	7.49	1.91	7.65	1.93	8.14	1.98	8.47	2.02
	25.0	6.64	1.91	6.97	1.94	7.29	1.98	7.46	2.00	7.95	2.05	8.27	2.08
	32.0	6.18	2.07	6.51	2.11	6.83	2.14	7.00	2.16	7.49	2.21	7.81	2.24
	35.0	5.99	2.15	6.31	2.18	6.64	2.22	6.80	2.23	7.29	2.28	7.61	2.32
	40.0	5.66	2.28	5.98	2.31	6.31	2.35	6.47	2.36	6.96	2.42	7.28	2.45
	43.0	5.46	2.36	5.79	2.40	6.11	2.43	6.27	2.46	6.76	2.50	7.09	2.54
46.0	4.92	2.14	5.18	2.14	5.42	2.14	5.55	2.14	5.90	2.14	6.13	2.14	
1.5+2.0+4+2	22.0	6.84	1.81	7.17	1.84	7.49	1.87	7.65	1.89	8.14	1.94	8.47	1.98
	25.0	6.64	1.87	6.97	1.90	7.29	1.94	7.46	1.96	7.95	2.01	8.27	2.04
	32.0	6.18	2.03	6.51	2.07	6.83	2.10	7.00	2.12	7.49	2.17	7.81	2.20
	35.0	5.99	2.11	6.31	2.14	6.64	2.18	6.80	2.19	7.29	2.24	7.61	2.28
	40.0	5.66	2.24	5.98	2.27	6.31	2.31	6.47	2.32	6.96	2.38	7.28	2.41
	43.0	5.46	2.32	5.79	2.36	6.11	2.39	6.27	2.42	6.76	2.46	7.09	2.50
46.0	4.92	2.10	5.18	2.10	5.42	2.10	5.55	2.10	5.90	2.10	6.13	2.10	
1.5+2.0+5+5.0	22.0	7.24	1.75	7.58	1.78	7.92	1.82	8.08	1.84	8.59	1.89	8.92	1.93
	25.0	7.04	1.81	7.38	1.85	7.71	1.89	7.88	1.90	8.38	1.96	8.72	1.99
	32.0	6.56	1.98	6.90	2.02	7.24	2.06	7.40	2.07	7.91	2.13	8.24	2.16
	35.0	6.36	2.06	6.70	2.10	7.03	2.13	7.20	2.15	7.70	2.21	8.04	2.24
	40.0	6.02	2.20	6.36	2.24	6.69	2.27	6.86	2.29	7.36	2.35	7.70	2.38
	43.0	5.82	2.29	6.15	2.32	6.49	2.36	6.66	2.38	7.16	2.43	7.50	2.47
46.0	5.17	1.96	5.42	1.96	5.66	1.96	5.78	1.96	6.14	1.96	6.37	1.96	

Notes

- The capacities are based on the following conditions:
Corresponding refrigerant piping length: ·5·m
Level difference: ·0·m
The bold cells indicate the standard conditios.
- The values above are for connecting with the following indoor unit types:
· 1.5, 2.0, 2.5, 3.5, 4.2, 5.0 · kW class
Wall-mountend ·CTXM-M, FTXM-M· series
- Editable data for this drawing are available in ·GDE· system.

Symbols

- TC: Total capacity [kW]
PI: Power input [kW]
① Indoor unit combinations
② Outdoor air temperature
[° C DB]