

①	②	Indoor air temperature [°C DB]											
		16°C		18°C		20°C		21°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
1.5	-15.0	1.73	0.86	1.67	0.87	1.62	0.88	1.60	0.89	1.57	0.89	1.52	0.90
	-10.0	2.15	0.91	2.10	0.92	2.04	0.93	2.02	0.94	1.99	0.94	1.94	0.95
	-5.0	2.57	0.96	2.52	0.97	2.47	0.98	2.44	0.99	2.42	0.99	2.36	1.00
	0.0	3.00	1.01	2.94	1.02	2.89	1.03	2.87	1.04	2.84	1.04	2.79	1.05
	6.0	3.50	1.07	3.45	1.08	3.40	1.09	3.37	1.10	3.35	1.10	3.30	1.11
	10.0	3.84	1.11	3.79	1.12	3.74	1.13	3.71	1.13	3.69	1.14	3.64	1.15
	15.0	4.27	1.16	4.21	1.17	4.16	1.18	4.14	1.18	4.11	1.19	4.06	1.20
2.0	-15.0	2.13	1.04	2.07	1.05	2.02	1.06	2.00	1.07	1.97	1.07	1.92	1.08
	-10.0	2.55	1.09	2.50	1.10	2.44	1.11	2.42	1.12	2.39	1.12	2.34	1.13
	-5.0	2.97	1.14	2.92	1.15	2.87	1.16	2.84	1.17	2.82	1.17	2.76	1.18
	0.0	3.40	1.19	3.34	1.20	3.29	1.21	3.27	1.22	3.24	1.22	3.19	1.23
	6.0	3.90	1.25	3.85	1.26	3.80	1.27	3.77	1.28	3.75	1.28	3.70	1.29
	10.0	4.24	1.29	4.19	1.30	4.14	1.31	4.11	1.31	4.09	1.32	4.04	1.33
	15.0	4.67	1.34	4.61	1.35	4.56	1.36	4.54	1.36	4.51	1.37	4.46	1.38
2.5	-15.0	2.53	1.13	2.47	1.14	2.42	1.15	2.40	1.16	2.37	1.16	2.32	1.17
	-10.0	2.95	1.18	2.90	1.19	2.84	1.20	2.82	1.21	2.79	1.21	2.74	1.22
	-5.0	3.37	1.23	3.32	1.24	3.27	1.25	3.24	1.30	3.22	1.30	3.16	1.31
	0.0	3.80	1.28	3.74	1.29	3.69	1.30	3.67	1.31	3.64	1.31	3.59	1.32
	6.0	4.30	1.34	4.25	1.35	4.20	1.36	4.17	1.37	4.15	1.37	4.10	1.38
	10.0	4.64	1.38	4.59	1.39	4.54	1.40	4.51	1.40	4.49	1.41	4.44	1.42
	15.0	5.07	1.43	5.01	1.44	4.96	1.45	4.94	1.45	4.91	1.46	4.86	1.47
3.5	-15.0	2.65	1.42	2.58	1.43	2.51	1.45	2.48	1.46	2.45	1.46	2.38	1.48
	-10.0	3.19	1.49	3.12	1.50	3.06	1.52	3.03	1.53	2.99	1.53	2.93	1.55
	-5.0	3.74	1.56	3.67	1.57	3.60	1.59	3.57	1.60	3.54	1.60	3.47	1.62
	0.0	4.28	1.63	4.21	1.64	4.15	1.66	4.11	1.66	4.08	1.67	4.01	1.69
	6.0	4.93	1.71	4.87	1.72	4.80	1.74	4.77	1.75	4.73	1.76	4.67	1.77
	10.0	5.37	1.77	5.30	1.78	5.24	1.80	5.20	1.80	5.17	1.81	5.10	1.83
	15.0	5.91	1.83	5.85	1.85	5.78	1.86	5.75	1.87	5.71	1.88	5.65	1.89
4.2	-15.0	3.45	1.71	3.38	1.72	3.31	1.74	3.28	1.75	3.25	1.75	3.18	1.77
	-10.0	3.99	1.78	3.92	1.79	3.86	1.81	3.83	1.82	3.79	1.82	3.73	1.84
	-5.0	4.54	1.85	4.47	1.86	4.40	1.88	4.37	1.89	4.34	1.89	4.27	1.91
	0.0	5.08	1.92	5.01	1.93	4.95	1.95	4.91	1.95	4.88	1.96	4.81	1.98
	6.0	5.73	2.00	5.67	2.01	5.60	2.03	5.57	2.04	5.53	2.05	5.47	2.06
	10.0	6.17	2.06	6.10	2.07	6.04	2.09	6.00	2.09	5.97	2.10	5.90	2.12
	15.0	6.71	2.12	6.65	2.14	6.58	2.15	6.55	2.16	6.51	2.17	6.45	2.18
5.0	-15.0	3.77	2.09	3.67	2.11	3.58	2.13	3.53	2.14	3.49	2.16	3.39	2.18
	-10.0	4.53	2.19	4.44	2.22	4.35	2.24	4.30	2.25	4.25	2.26	4.16	2.29
	-5.0	5.30	2.30	5.21	2.32	5.11	2.35	5.07	2.36	5.02	2.37	4.93	2.39
	0.0	6.07	2.41	5.97	2.43	5.88	2.45	5.83	2.46	5.79	2.48	5.69	2.50
	6.0	6.99	2.53	6.89	2.56	6.80	2.58	6.75	2.59	6.71	2.60	6.61	2.63
	10.0	7.60	2.62	7.51	2.64	7.41	2.67	7.34	2.68	7.16	2.69	6.80	2.72
	15.0	8.23	2.63	7.87	2.66	7.51	2.69	7.44	2.70	7.26	2.71	6.90	2.74

①	②	Indoor air temperature [°C DB]											
		16°C		18°C		20°C		21°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
1.5+1.5	-15.0	2.67	1.18	2.58	1.21	2.48	1.23	2.43	1.24	2.38	1.25	2.29	1.27
	-10.0	3.46	1.28	3.37	1.30	3.27	1.32	3.22	1.33	3.17	1.34	3.08	1.36
	-5.0	4.25	1.37	4.16	1.39	4.06	1.41	4.02	1.42	3.96	1.43	3.87	1.45
	0.0	5.04	1.47	4.95	1.49	4.85	1.51	4.80	1.52	4.75	1.53	4.66	1.55
	6.0	5.99	1.58	5.90	1.60	5.80	1.62	5.75	1.63	5.70	1.64	5.61	1.66
	10.0	6.63	1.65	6.53	1.67	6.43	1.70	6.38	1.71	6.34	1.72	6.24	1.74
	15.0	7.42	1.75	7.32	1.77	7.22	1.79	7.17	1.80	7.13	1.81	7.03	1.83
1.5+2.0	-15.0	2.67	1.16	2.58	1.19	2.48	1.21	2.43	1.22	2.38	1.23	2.29	1.25
	-10.0	3.46	1.26	3.37	1.28	3.27	1.30	3.22	1.31	3.17	1.32	3.08	1.34
	-5.0	4.25	1.35	4.16	1.37	4.06	1.39	4.01	1.40	3.96	1.41	3.87	1.43
	0.0	5.04	1.45	4.95	1.47	4.85	1.49	4.80	1.50	4.75	1.51	4.66	1.53
	6.0	5.99	1.56	5.90	1.58	5.80	1.60	5.75	1.61	5.70	1.62	5.61	1.64
	10.0	6.63	1.63	6.53	1.65	6.43	1.68	6.38	1.69	6.34	1.70	6.24	1.72
	15.0	7.42	1.73	7.32	1.75	7.22	1.77	7.17	1.78	7.13	1.79	7.03	1.81
1.5+2.5	-15.0	3.77	1.63	3.68	1.65	3.58	1.67	3.53	1.68	3.48	1.69	3.39	1.71
	-10.0	4.56	1.72	4.47	1.74	4.37	1.76	4.32	1.77	4.27	1.78	4.18	1.80
	-5.0	5.35	1.82	5.26	1.84	5.16	1.86	5.11	1.87	5.06	1.88	4.97	1.90
	0.0	6.14	1.91	6.05	1.93	5.95	1.95	5.90	1.96	5.85	1.97	5.76	1.99
	6.0	7.09	2.02	7.00	2.04	6.90	2.06	6.85	2.07	6.80	2.08	6.71	2.10
	10.0	7.73	2.09	7.63	2.11	7.53	2.13	7.48	2.14	7.44	2.15	7.34	2.17
	15.0	8.52	2.19	8.42	2.21	8.32	2.23	8.27	2.24	8.23	2.25	8.13	2.27
1.5+3.5	-15.0	3.86	1.81	3.76	1.84	3.66	1.86	3.61	1.87	3.56	1.88	3.47	1.90
	-10.0	4.65	1.91	4.55	1.93	4.46	1.95	4.41	1.96	4.36	1.97	4.26	1.99
	-5.0	5.45	2.00	5.35	2.02	5.25	2.04	5.20	2.05	5.15	2.06	5.06	2.08
	0.0	6.24	2.10	6.14	2.12	6.05	2.14	6.00	2.15	5.95	2.16	5.85	2.18
	6.0	7.19	2.21	7.10	2.23	7.00	2.25	6.95	2.26	6.90	2.27	6.81	2.29
	10.0	7.83	2.28	7.73	2.30	7.64	2.33	7.59	2.34	7.54	2.35	7.44	2.37
	15.0	8.63	2.38	8.53	2.40	8.43	2.42	8.38	2.43	8.33	2.44	8.24	2.46
1.5+4.2	-15.0	3.86	1.79	3.76	1.82	3.66	1.84	3.61	1.85	3.56	1.86	3.47	1.88
	-10.0	4.65	1.89	4.55	1.91	4.46	1.93	4.41	1.94	4.36	1.95	4.26	1.97
	-5.0	5.45	1.98	5.35	2.00	5.25	2.02	5.20	2.03	5.15	2.04	5.06	2.06
	0.0	6.24	2.08	6.14	2.10	6.05	2.12	6.00	2.13	5.95	2.14	5.85	2.16
	6.0	7.19	2.19	7.10	2.21	7.00	2.23	6.95	2.24	6.90	2.25	6.81	2.27
	10.0	7.83	2.26	7.73	2.28	7.64	2.31	7.59	2.32	7.54	2.33	7.44	2.35
	15.0	8.63	2.36	8.53	2.38	8.43	2.40	8.38	2.41	8.33	2.42	8.24	2.44
1.5+5.0	-15.0	3.98	1.86	3.88	1.88	3.79	1.90	3.74	1.91	3.69	1.92	3.59	1.94
	-10.0	4.80	1.95	4.70	1.97	4.60	1.99	4.55	2.00	4.50	2.02	4.40	2.04
	-5.0	5.61	2.05	5.51	2.07	5.41	2.09	5.36	2.10	5.31	2.11	5.21	2.13
	0.0	6.42	2.14	6.32	2.16	6.22	2.19	6.17	2.20	6.12	2.21	6.03	2.23
	6.0	7.40	2.26	7.30	2.28	7.20	2.30	7.15	2.31	7.10	2.32	7.00	2.34
	10.0	8.05	2.33	7.95	2.36	7.85	2.38	7.80	2.39	7.75	2.40	7.65	2.42
	15.0	8.86	2.43	8.76	2.45	8.66	2.47	8.61	2.48	8.56	2.49	8.46	2.51

Notes

- The capacities are based on the following conditions:
Corresponding refrigerant piping length: ·5 m
Level difference: ·0 m
- The bold cells indicate the standard conditios.
- The values above are for connecting with the following indoor unit types:
·1.5, 2.0, 2.5, 3.5, 4.2, 5.0 · kW class
Wall-mountend · CTXM-M, FTXM-M series

Symbols

- TC: Total capacity [kW]
- PI: Power input [kW]
- ① Indoor unit combinations
- ② Outdoor air temperature [° C WB]