

①	②	Indoor air temperature [°C DB]											
		16°C		18°C		20°C		21°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2.0+2.5+4.2	-15.0	4.50	1.71	4.39	1.73	4.28	1.75	4.23	1.75	4.17	1.76	4.06	1.78
	-10.0	5.41	1.79	5.30	1.81	5.19	1.83	5.14	1.84	5.08	1.85	4.97	1.87
	-5.0	6.32	1.88	6.21	1.90	6.10	1.92	6.04	1.93	5.99	1.94	5.88	1.96
	0.0	7.23	1.97	7.12	1.99	7.01	2.01	6.95	2.02	6.90	2.02	6.79	2.04
	6.0	8.38	2.07	8.21	2.09	8.10	2.11	8.04	2.12	7.99	2.13	7.88	2.15
	10.0	9.13	2.14	9.01	2.16	8.90	2.18	8.84	2.19	8.78	2.20	8.67	2.22
	15.0	10.06	2.23	9.95	2.25	9.83	2.27	9.77	2.28	9.72	2.29	9.60	2.31
2.0+3.5+3.5	-15.0	4.59	1.74	4.48	1.76	4.37	1.78	4.31	1.79	4.26	1.80	4.14	1.82
	-10.0	5.50	1.83	5.39	1.85	5.28	1.87	5.22	1.88	5.17	1.89	5.06	1.91
	-5.0	6.42	1.92	6.30	1.94	6.19	1.96	6.14	1.97	6.08	1.98	5.97	1.99
	0.0	7.33	2.01	7.22	2.02	7.11	2.04	7.05	2.05	6.99	2.06	6.88	2.08
	6.0	8.42	2.11	8.31	2.13	8.20	2.15	8.14	2.16	8.09	2.17	7.98	2.19
	10.0	9.15	2.18	9.04	2.20	8.93	2.22	8.87	2.23	8.82	2.24	8.71	2.26
	15.0	10.07	2.27	9.95	2.29	9.84	2.31	9.79	2.32	9.73	2.33	9.62	2.35
2.5+2.5+2.5	-15.0	4.42	1.66	4.31	1.68	4.20	1.70	4.14	1.71	4.09	1.72	3.97	1.74
	-10.0	5.32	1.75	5.21	1.77	5.10	1.79	5.05	1.80	4.99	1.81	4.88	1.83
	-5.0	6.23	1.84	6.12	1.86	6.01	1.88	5.95	1.89	5.90	1.90	5.79	1.91
	0.0	7.13	1.93	7.02	1.94	6.91	1.96	6.86	1.97	6.80	1.98	6.69	2.00
	6.0	8.22	2.03	8.11	2.05	8.00	2.07	7.94	2.08	7.89	2.09	7.78	2.11
	10.0	8.95	2.10	8.84	2.12	8.72	2.14	8.67	2.15	8.61	2.16	8.50	2.18
	15.0	9.85	2.19	9.74	2.21	9.63	2.23	9.57	2.24	9.52	2.25	9.41	2.27
2.5+2.5+3.5	-15.0	4.50	1.68	4.39	1.70	4.28	1.72	4.23	1.73	4.17	1.74	4.06	1.76
	-10.0	5.41	1.77	5.30	1.79	5.19	1.81	5.14	1.82	5.08	1.83	4.97	1.85
	-5.0	6.32	1.86	6.21	1.88	6.10	1.90	6.04	1.91	5.99	1.92	5.88	1.93
	0.0	7.23	1.95	7.12	1.96	7.01	1.98	6.95	1.99	6.90	2.00	6.79	2.02
	6.0	8.32	2.05	8.21	2.07	8.10	2.09	8.04	2.10	7.99	2.11	7.88	2.13
	10.0	9.05	2.12	8.94	2.14	8.83	2.16	8.77	2.17	8.72	2.18	8.60	2.20
	15.0	9.96	2.21	9.85	2.23	9.74	2.25	9.68	2.26	9.63	2.27	9.51	2.29

Notes

- The capacities are based on the following conditions:  
Corresponding refrigerant piping length: · 5·m  
Level difference: · 0·m
- The bold cells indicate the standard conditios.
- The values above are for connecting with the following indoor unit types:  
· 2.0, 2.5, 3.5, 4.2 · kW class  
Wall-mountend · CTXM-M, FTXM-M series

Symbols

- TC: Total capacity [kW]
- PI: Power input [kW]
- ① Indoor unit combinations
- ② Outdoor air temperature [° C WB]