

①	②	Indoor air temperature [°C DB]											
		16°C			18°C			20°C			21°C		
		TC	PI	TC	TC	PI	TC	TC	PI	TC	TC	PI	TC
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
4.2+4.2	-15.0	4.08	190	3.98	192	3.88	194	3.83	195	3.78	196	3.68	199
	-10.0	4.89	2.00	4.79	2.02	4.69	2.04	4.64	2.05	4.59	2.06	4.49	2.08
	-5.0	5.71	2.09	5.61	2.12	5.51	2.14	5.46	2.15	5.41	2.16	5.31	2.18
	0.0	6.52	2.19	6.42	2.21	6.32	2.23	6.27	2.24	6.22	2.26	6.12	2.28
	6.0	7.50	2.31	7.40	2.33	7.30	2.35	7.25	2.36	7.20	2.37	7.10	2.39
	10.0	8.15	2.39	8.05	2.41	7.95	2.43	7.90	2.44	7.85	2.45	7.75	2.47
	15.0	8.97	2.48	8.87	2.50	8.77	2.52	8.72	2.53	8.67	2.55	8.57	2.57
1.5+1.5+1.5	-15.0	4.42	171	4.31	173	4.20	175	4.14	176	4.09	177	3.97	179
	-10.0	5.32	180	5.21	182	5.10	184	5.05	185	4.99	186	4.88	188
	-5.0	6.23	189	6.12	191	6.01	193	5.95	194	5.90	195	5.79	198
	0.0	7.13	198	7.02	199	6.91	2.01	6.86	2.02	6.80	2.03	6.69	2.05
	6.0	8.22	2.08	8.11	2.10	8.00	2.12	7.94	2.13	7.89	2.14	7.78	2.16
	10.0	8.95	2.15	8.84	2.17	8.72	2.19	8.67	2.20	8.61	2.21	8.50	2.23
	15.0	9.85	2.24	9.74	2.26	9.63	2.28	9.57	2.29	9.52	2.30	9.41	2.32
1.5+1.5+2.0	-15.0	4.42	169	4.31	171	4.20	173	4.14	174	4.09	175	3.97	177
	-10.0	5.32	178	5.21	180	5.10	182	5.05	183	4.99	184	4.88	186
	-5.0	6.23	187	6.12	189	6.01	191	5.95	192	5.90	193	5.79	194
	0.0	7.13	196	7.02	197	6.91	199	6.86	2.00	6.80	2.01	6.69	2.03
	6.0	8.22	2.06	8.11	2.08	8.00	2.10	7.94	2.11	7.89	2.12	7.78	2.14
	10.0	8.95	2.13	8.84	2.15	8.72	2.17	8.67	2.18	8.61	2.19	8.50	2.21
	15.0	9.85	2.22	9.74	2.24	9.63	2.26	9.57	2.27	9.52	2.28	9.41	2.30
1.5+1.5+2.5	-15.0	4.42	167	4.31	169	4.20	171	4.14	172	4.09	173	3.97	175
	-10.0	5.32	176	5.21	178	5.10	180	5.05	181	4.99	182	4.88	184
	-5.0	6.23	185	6.12	187	6.01	189	5.95	190	5.90	191	5.79	192
	0.0	7.13	194	7.02	195	6.91	197	6.86	198	6.80	199	6.69	2.01
	6.0	8.22	2.04	8.11	2.06	8.00	2.08	7.94	2.09	7.89	2.10	7.78	2.12
	10.0	8.95	2.11	8.84	2.13	8.72	2.15	8.67	2.16	8.61	2.17	8.50	2.19
	15.0	9.85	2.20	9.74	2.22	9.63	2.24	9.57	2.25	9.52	2.26	9.41	2.28
1.5+1.5+3.5	-15.0	4.50	172	4.39	174	4.28	176	4.23	177	4.17	178	4.06	180
	-10.0	5.41	181	5.30	183	5.19	185	5.14	186	5.08	187	4.97	189
	-5.0	6.32	190	6.21	192	6.10	194	6.04	195	5.99	196	5.88	197
	0.0	7.23	199	7.12	2.00	7.01	2.02	6.95	2.03	6.90	2.04	6.79	2.06
	6.0	8.32	2.09	8.21	2.11	8.10	2.13	8.04	2.14	7.99	2.15	7.88	2.17
	10.0	9.05	2.16	8.94	2.18	8.83	2.20	8.77	2.21	8.72	2.22	8.60	2.24
	15.0	9.96	2.25	9.85	2.27	9.74	2.29	9.68	2.30	9.63	2.31	9.51	2.33
1.5+1.5+4.2	-15.0	4.50	170	4.39	172	4.28	174	4.23	175	4.17	176	4.06	178
	-10.0	5.41	179	5.30	181	5.19	183	5.14	184	5.08	185	4.97	187
	-5.0	6.32	188	6.21	190	6.10	192	6.04	193	5.99	194	5.88	195
	0.0	7.23	197	7.12	198	7.01	2.00	6.95	2.01	6.90	2.02	6.79	2.04
	6.0	8.32	2.07	8.21	2.09	8.10	2.11	8.04	2.12	7.99	2.13	7.88	2.15
	10.0	9.05	2.14	8.94	2.16	8.83	2.18	8.77	2.19	8.72	2.20	8.60	2.22
	15.0	9.96	2.23	9.85	2.25	9.74	2.27	9.68	2.28	9.63	2.29	9.51	2.31

①	②	Indoor air temperature [°C DB]											
		16°C			18°C			20°C			21°C		
		TC	PI	TC	TC	PI	TC	TC	PI	TC	TC	PI	TC
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
1.5+1.5+5.0	-15.0	4.61	169	4.49	171	4.38	173	4.32	173	4.26	174	4.15	176
	-10.0	5.54	177	5.43	179	5.31	181	5.25	182	5.20	183	5.08	185
	-5.0	6.47	186	6.36	188	6.25	190	6.19	191	6.13	192	6.02	194
	0.0	7.41	195	7.29	197	7.18	199	7.12	2.00	7.07	2.00	6.95	2.02
	6.0	8.53	2.05	8.41	2.07	8.30	2.09	8.24	2.10	8.19	2.11	8.07	2.13
	10.0	9.28	2.12	9.16	2.14	9.05	2.16	8.99	2.17	8.93	2.18	8.82	2.20
	15.0	10.21	2.21	10.10	2.23	9.98	2.25	9.92	2.26	9.87	2.27	9.75	2.28
1.5+2.0+2.0	-15.0	4.42	173	4.31	175	4.20	177	4.14	178	4.09	179	3.97	181
	-10.0	5.32	182	5.21	184	5.10	186	5.05	187	4.99	188	4.88	190
	-5.0	6.23	191	6.12	193	6.01	195	5.95	196	5.90	197	5.79	198
	0.0	7.13	2.00	7.02	2.01	6.91	2.03	6.86	2.04	6.80	2.05	6.69	2.07
	6.0	8.22	2.10	8.11	2.12	8.00	2.14	7.94	2.15	7.89	2.16	7.78	2.18
	10.0	8.95	2.17	8.84	2.19	8.72	2.21	8.67	2.22	8.61	2.23	8.50	2.25
	15.0	9.85	2.26	9.74	2.28	9.63	2.30	9.57	2.31	9.52	2.32	9.41	2.34
1.5+2.0+2.5	-15.0	4.42	171	4.31	173	4.20	175	4.14	176	4.09	177	3.97	179
	-10.0	5.32	180	5.21	182	5.10	184	5.05	185	4.99	186	4.88	188
	-5.0	6.23	189	6.12	191	6.01	193	5.95	194	5.90	195	5.79	196
	0.0	7.13	198	7.02	199	6.91	2.01	6.86	2.02	6.80	2.03	6.69	2.05
	6.0	8.22	2.08	8.11	2.10	8.00	2.12	7.94	2.13	7.89	2.14	7.78	2.16
	10.0	8.95	2.15	8.84	2.17	8.72	2.19	8.67	2.20	8.61	2.21	8.50	2.23
	15.0	9.85	2.24	9.74	2.26	9.63	2.28	9.57	2.29	9.52	2.30	9.41	2.32
1.5+2.0+3.5	-15.0	4.50	175	4.39	177	4.28	179	4.23	180	4.17	181	4.06	183
	-10.0	5.41	184	5.30	186	5.19	188	5.14	189	5.08	190	4.97	192
	-5.0	6.32	193	6.21	195	6.10	197	6.04	198	5.99	199	5.88	2.00
	0.0	7.23	2.02	7.12	2.03	7.01	2.05	6.95	2.06	6.90	2.07	6.79	2.09
	6.0	8.32	2.12	8.21	2.14	8.10	2.16	8.04	2.17	7.99	2.18	7.88	2.20
	10.0	9.05	2.19	8.94	2.21	8.83	2.23	8.77	2.24	8.72	2.25	8.60	2.27
	15.0	9.96	2.28	9.85	2.30	9.74	2.32	9.68	2.33	9.63	2.34	9.51	2.36
1.5+2.0+4.2	-15.0	4.50	173	4.39	175	4.28	177	4.23	178	4.17	179	4.06	181
	-10.0	5.41	182	5.30	184	5.19	186	5.14	187	5.08	188	4.97	190
	-5.0	6.32	191	6.21	193	6.10	195	6.04	196	5.99	197	5.88	198
	0.0	7.23	2.00	7.12	2.01	7.01	2.03	6.95	2.04	6.90	2.05	6.79	2.07
	6.0	8.32	2.10	8.21	2.12	8.10	2.14	8.04	2.15	7.99	2.16	7.88	2.18
	10.0	9.05	2.17	8.94	2.19	8.83	2.21	8.77	2.22	8.72	2.23	8.60	2.25
	15.0	9.96	2.26	9.85	2.28	9.74	2.30	9.68	2.31	9.63	2.32	9.51	2.34
1.5+2.0+5.0	-15.0	4.61	167	4.49	169	4.38	171	4.32	171	4.26	172	4.15	174
	-10.0	5.54	175	5.43	177	5.31	179	5.25	180	5.20	181	5.08	183
	-5.0	6.47	184	6.36	186	6.25	188	6.19	189	6.13	190	6.02	192
	0.0	7.41	193	7.29	195	7.18	197	7.12	198	7.07	198	6.95	2.00
	6.0	8.53	2.03	8.41	2.05	8.30	2.07	8.24	2.08	8.19	2.09	8.07	2.11
	10.0	9.28	2.10	9.16	2.12	9.05	2.14	8.99	2.15	8.93	2.16	8.82	2.18
	15.0	10.21	2.19	10.10	2.21	9.98	2.23	9.92	2.24	9.87	2.25	9.75	2.26

Notes

- 1. The capacities are based on the following conditions:
Corresponding refrigerant piping length: ·5·m
Level difference: ·0·m
- 2. The bold cells indicate the standard conditios.
- 3. The values above are for connecting with the following indoor unit types:
·1.5, 2.0, 2.5, 3.5, 4.2, 5.0· kW class
Wall-mounted ·CTXM-M, FTXM-M· series
- 4. Editable data for this drawing are available in ·GDE· system.

Symbols

- TC: Total capacity [kW]
- PI: Power input [kW]
- ① Indoor unit combinations
- ② Outdoor air temperature
[° C WB]