
## External connection diagram



## Notes

- 1. All wiring, components and materials to be procured on-site must comply with the applicable legislation.
- 2. Use copper conductors only
- 3. For more details, refer to the wiring diagram of the unit.
- 4. Install a circuit breaker for safety.
- 5. All field wiring and components must be provided by an authorised electrician.
- 6. Unit has to be grounded in compliance with the applicable legislation.
- 7. The wiring shown is a general points-of-connection guide and is not intended to include all details for a specific installation.
- 8. Make sure to install the switch and the fuse to the power line of each equipement.
- 9. Install a main to switch to (if necessary) immediately interrupt all the system's power sources.
- 10. If there exists the possibility of reversed phase, loose phase or momentary blackout, or if the power goes on and off while the product is operating, attach a reversed phase protection circuit locally.
- 11. Install an earth leakage circuit breaker.