

Cooling ·50Hz 230V·

①	②	Indoor air temperature [°C WB]											
		14°C		16°C		18°C		19°C		22°C		24°C	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
		kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
2.0+2.5+2.5+3.5	22,0	8,68	2,64	9,05	2,70	9,42	2,75	9,61	2,78	10,18	2,87	10,55	2,93
	25,0	8,45	2,74	8,83	2,80	9,20	2,86	9,39	2,89	9,95	2,98	10,31	3,04
	32,0	7,91	3,02	8,29	3,07	8,67	3,13	8,85	3,16	9,42	3,24	9,79	3,30
	35,0	7,68	3,14	8,06	3,20	8,44	3,26	8,63	3,28	9,19	3,37	9,56	3,43
	40,0	7,30	3,36	7,68	3,42	8,06	3,47	8,25	3,50	8,81	3,58	9,19	3,64
	43,0	6,67	2,98	6,96	2,98	7,24	2,98	7,38	2,98	7,79	2,98	8,05	2,98
	46,0	5,66	2,30	5,88	2,30	6,10	2,30	6,21	2,30	6,53	2,30	6,73	2,30
2.5+2.5+2.5+2.5	22,0	8,60	2,66	8,98	2,70	9,35	2,76	9,53	2,78	10,10	2,85	10,47	2,91
	25,0	8,38	2,74	8,75	2,80	9,12	2,84	9,31	2,87	9,87	2,96	10,23	3,01
	32,0	7,85	3,00	8,23	3,05	8,59	3,11	8,78	3,14	9,34	3,22	9,71	3,28
	35,0	7,62	3,12	8,00	3,18	8,37	3,23	8,56	3,26	9,12	3,34	9,49	3,40
	40,0	7,24	3,33	7,62	3,39	7,99	3,45	8,18	3,48	8,74	3,56	9,11	3,62
	43,0	7,09	3,42	7,39	3,42	7,68	3,42	7,83	3,42	8,25	3,42	8,52	3,42
	46,0	6,05	2,73	6,28	2,73	6,51	2,73	6,62	2,73	6,95	2,73	7,16	2,73
2.5+2.5+2.5+3.5	22,0	8,95	2,73	9,34	2,79	9,72	2,84	9,92	2,87	10,50	2,96	10,89	3,02
	25,0	8,72	2,83	9,11	2,89	9,49	2,95	9,69	2,98	10,27	3,07	10,64	3,13
	32,0	8,17	3,11	8,56	3,17	8,94	3,23	9,14	3,26	9,72	3,34	10,11	3,40
	35,0	7,93	3,24	8,32	3,30	8,71	3,36	8,90	3,38	9,49	3,47	9,87	3,53
	40,0	7,53	3,46	7,93	3,52	8,32	3,58	8,51	3,61	9,09	3,69	9,48	3,75
	43,0	6,94	3,10	7,23	3,10	7,51	3,10	7,65	3,10	8,06	3,10	8,32	3,10
	46,0	5,93	2,44	6,15	2,44	6,37	2,44	6,48	2,44	6,80	2,44	7,00	2,44

Symbols

TC: Total capacity [kW]

PI: Power input [kW]

① Indoor unit combinations

② Outdoor air temperature [°C DB]