

5MWM68A9

Cooling 230V 50Hz

Outdoor unit	Indoor unit	Cooling capacity [kW]				Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room -A-	Room -B-	Room -C-	Room -D-	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
5MWM68A2V189	1.5	1.60	-	-	-	3.05	1.60	2.49	0.57	0.30	0.59	3.00	1.60	3.00	84
	2.0	2.00	-	-	-	3.05	2.00	3.00	0.57	0.37	0.71	3.00	2.00	3.70	84
	2.5	2.50	-	-	-	3.04	2.50	3.44	0.57	0.47	0.81	3.00	2.50	4.20	84
	3.5	3.50	-	-	-	3.02	3.50	4.22	0.57	0.82	1.22	2.90	4.10	6.10	87
	4.2	4.20	-	-	-	3.01	4.20	4.64	0.56	1.21	1.47	2.80	5.90	7.20	89
	5.0	5.00	-	-	-	2.99	5.00	6.03	0.56	1.69	2.13	2.80	8.30	10.40	89
	6.0	6.00	-	-	-	2.92	6.00	6.51	0.55	2.03	2.30	2.70	9.80	11.00	91
	1.5+1.5	1.50	1.50	-	-	2.79	3.00	4.77	0.52	0.58	1.22	2.60	3.00	6.10	87
	1.5+2.0	1.50	2.00	-	-	2.79	3.50	4.77	0.52	0.75	1.22	2.60	3.80	6.10	87
	1.5+2.5	1.50	2.50	-	-	2.79	4.00	5.28	0.52	0.92	1.47	2.60	4.50	7.20	89
	1.5+3.5	1.50	3.50	-	-	2.78	5.00	5.39	0.52	1.31	1.49	2.60	6.40	7.30	89
	1.5+4.2	1.50	4.20	-	-	2.77	5.70	5.86	0.52	1.66	1.73	2.50	8.00	8.30	91
	1.5+5.0	1.50	5.00	-	-	2.76	6.50	6.66	0.51	2.09	2.20	2.50	9.80	10.20	93
	1.5+6.0	1.36	5.44	-	-	2.74	6.80	7.59	0.51	2.19	2.81	2.30	9.90	12.60	97
	2.0+2.0	2.00	2.00	-	-	2.79	4.00	5.12	0.52	0.92	1.43	2.60	4.50	7.00	89
	2.0+2.5	2.00	2.50	-	-	2.79	4.50	5.36	0.52	1.12	1.49	2.60	5.50	7.30	89
	2.0+3.5	2.00	3.50	-	-	2.78	5.50	5.84	0.52	1.57	1.73	2.50	7.60	8.30	91
	2.0+4.2	2.00	4.20	-	-	2.77	6.20	6.51	0.52	1.93	2.14	2.50	9.10	10.00	93
	2.0+5.0	1.94	4.86	-	-	2.76	6.80	6.95	0.51	2.31	2.41	2.40	10.60	11.10	95
	2.0+6.0	1.70	5.10	-	-	2.74	6.80	7.64	0.51	2.19	2.83	2.30	9.90	12.70	97
	2.5+2.5	2.50	2.50	-	-	2.78	5.00	5.37	0.52	1.33	1.49	2.60	6.50	7.30	89
	2.5+3.5	2.50	3.50	-	-	2.78	6.00	6.11	0.52	1.82	1.88	2.50	8.70	8.90	92
	2.5+4.2	2.50	4.20	-	-	2.77	6.70	6.95	0.51	2.28	2.45	2.40	10.50	11.20	95
	2.5+5.0	2.27	4.53	-	-	2.76	6.80	7.37	0.51	2.30	2.79	2.40	10.40	12.50	97
	2.5+6.0	2.00	4.80	-	-	2.74	6.80	7.66	0.51	2.16	2.84	2.30	9.80	12.70	97
	3.5+3.5	3.40	3.40	-	-	2.77	6.80	7.13	0.51	2.34	2.61	2.40	10.70	11.90	96
	3.5+4.2	3.09	3.71	-	-	2.76	6.80	7.24	0.51	2.30	2.75	2.40	10.40	12.30	97
	3.5+5.0	2.80	4.00	-	-	2.76	6.80	7.48	0.51	2.28	2.82	2.40	10.30	12.70	97
	3.5+6.0	2.51	4.29	-	-	2.73	6.80	8.07	0.50	2.15	3.42	2.30	9.50	15.00	99
	4.2+4.2	3.40	3.40	-	-	2.76	6.80	7.14	0.51	2.29	2.70	2.40	10.30	12.10	97
	4.2+5.0	3.10	3.70	-	-	2.75	6.80	7.77	0.51	2.24	3.35	2.30	9.90	14.70	99
	4.2+6.0	2.80	4.00	-	-	2.73	6.80	8.08	0.50	2.14	3.42	2.30	9.40	15.00	99
	5.0+5.0	3.40	3.40	-	-	2.74	6.80	8.17	0.51	2.20	3.50	2.30	9.70	15.40	99
	5.0+6.0	3.09	3.71	-	-	2.73	6.80	8.41	0.50	2.10	3.54	2.30	9.30	15.50	99
	1.5+1.5+1.5	1.50	1.50	1.50	-	2.72	4.50	5.91	0.50	1.00	1.51	2.50	4.90	7.40	89
	1.5+1.5+2.0	1.44	1.44	1.92	-	2.72	4.80	5.91	0.50	1.09	1.51	2.50	5.40	7.40	89
	1.5+1.5+2.5	1.36	1.36	2.27	-	2.72	5.00	6.46	0.50	1.17	1.76	2.40	5.60	8.50	91
	1.5+1.5+3.5	1.50	1.50	3.50	-	2.72	6.50	7.11	0.49	1.79	2.17	2.40	8.40	10.10	93
	1.5+1.5+4.2	1.42	1.42	3.97	-	2.72	6.80	7.33	0.49	1.92	2.24	2.40	9.00	10.40	93
	1.5+1.5+5.0	1.28	1.28	4.25	-	2.73	6.80	7.74	0.49	1.91	2.70	2.30	8.60	12.20	97
	1.5+1.5+6.0	1.13	1.13	4.53	-	2.74	6.80	7.99	0.49	1.86	3.17	2.20	8.20	13.90	99
	1.5+2.0+2.0	1.50	2.00	2.00	-	2.72	5.50	6.45	0.50	1.35	1.76	2.40	6.50	8.50	91
	1.5+2.0+2.5	1.50	2.00	2.50	-	2.72	6.00	6.46	0.50	1.55	1.76	2.40	7.50	8.50	91
	1.5+2.0+3.5	1.46	1.94	3.40	-	2.72	6.80	7.25	0.49	1.95	2.22	2.40	9.10	10.30	93
	1.5+2.0+4.2	1.32	1.77	3.71	-	2.72	6.80	7.47	0.49	1.92	2.62	2.30	8.70	11.80	97
1.5+2.0+5.0	1.20	1.60	4.00	-	2.73	6.80	7.87	0.49	1.91	2.75	2.30	8.60	12.40	97	
1.5+2.0+6.0	1.07	1.43	4.29	-	2.74	6.80	8.13	0.49	1.86	3.22	2.20	8.20	14.10	99	
1.5+2.5+2.5	1.50	2.50	2.50	-	2.72	6.50	7.10	0.50	1.80	2.17	2.40	8.40	10.10	93	
1.5+2.5+3.5	1.36	2.27	3.17	-	2.72	6.80	7.60	0.49	1.92	2.67	2.30	8.70	12.00	97	
1.5+2.5+4.2	1.24	2.07	3.48	-	2.72	6.80	7.81	0.49	1.92	2.74	2.30	8.70	12.30	97	
1.5+2.5+5.0	1.13	1.89	3.78	-	2.73	6.80	7.95	0.49	1.91	3.19	2.20	8.40	14.00	99	