

5MWM68A9

Heating 230V 50Hz

Outdoor unit	Indoor unit	Heating capacity [kW]				Total capacity [kW]			Power input [kW]			Total current [A]			Power factor [%]
		Room -A-	Room -B-	Room -C-	Room -D-	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	Minimum	Nominal	Maximum	
	1.5	2.70	-	-	-	2.34	2.70	4.08	0.49	0.60	1.19	2.60	3.10	6.10	86
	2.0	3.00	-	-	-	2.34	3.00	4.09	0.49	0.69	1.19	2.60	3.50	6.10	86
	2.5	3.40	-	-	-	2.34	3.40	4.30	0.49	0.80	1.24	2.50	4.10	6.30	86
	3.5	4.30	-	-	-	2.34	4.30	4.90	0.49	1.11	1.66	2.40	5.50	8.10	89
	4.2	5.00	-	-	-	2.34	5.00	5.70	0.48	1.35	2.61	2.20	6.00	11.70	98
	5.0	6.00	-	-	-	2.35	6.00	6.90	0.47	1.76	3.06	2.20	7.90	13.60	98
	6.0	7.20	-	-	-	2.35	7.20	8.91	0.46	2.29	3.78	2.10	10.20	16.80	98
	1.5+1.5	1.85	1.85	-	-	2.34	3.70	6.96	0.45	0.82	2.00	2.20	4.00	9.80	89
	1.5+2.0	1.80	2.40	-	-	2.34	4.20	6.96	0.45	0.98	2.00	2.20	4.80	9.80	89
	1.5+2.5	1.80	3.00	-	-	2.34	4.80	7.95	0.44	1.16	3.02	2.10	5.20	13.50	98
	1.5+3.5	1.80	4.20	-	-	2.34	6.00	8.50	0.44	1.61	3.23	2.10	7.20	14.40	98
	1.5+4.2	1.82	5.08	-	-	2.34	6.90	8.85	0.44	1.94	3.26	2.00	8.70	14.50	98
	1.5+5.0	1.82	6.08	-	-	2.34	7.90	10.38	0.43	2.36	3.75	2.00	10.50	16.60	98
	1.5+6.0	1.72	6.88	-	-	2.48	8.60	10.53	0.46	2.59	3.63	2.10	11.50	16.10	98
	2.0+2.0	2.40	2.40	-	-	2.34	4.80	7.95	0.45	1.17	3.07	2.10	5.30	13.70	98
	2.0+2.5	2.40	3.00	-	-	2.34	5.40	8.12	0.44	1.39	3.09	2.10	6.20	13.80	98
	2.0+3.5	2.40	4.20	-	-	2.34	6.60	8.67	0.44	1.88	3.30	2.10	8.40	14.70	98
	2.0+4.2	2.42	5.08	-	-	2.34	7.50	9.03	0.44	2.22	3.33	2.00	9.90	14.80	98
	2.0+5.0	2.40	6.00	-	-	2.34	8.40	10.44	0.43	2.61	3.77	2.00	11.60	16.70	98
	2.0+6.0	2.15	6.45	-	-	2.48	8.60	10.53	0.46	2.59	3.63	2.10	11.50	16.10	98
	2.5+2.5	3.00	3.00	-	-	2.34	6.00	8.49	0.44	1.59	3.18	2.10	7.10	14.20	98
	2.5+3.5	3.00	4.20	-	-	2.34	7.20	9.03	0.44	2.12	3.42	2.00	9.40	15.20	98
	2.5+4.2	3.02	5.08	-	-	2.34	8.10	9.29	0.43	2.50	3.41	2.00	11.10	15.10	98
	2.5+5.0	2.87	5.73	-	-	2.34	8.60	10.47	0.43	2.69	3.73	2.00	11.90	16.50	98
	2.5+6.0	2.53	6.07	-	-	2.63	8.60	10.56	0.49	2.56	3.59	2.20	11.40	15.90	98
5MWM68A2V189	3.5+3.5	4.20	4.20	-	-	2.34	8.40	9.38	0.44	2.74	3.58	2.00	12.20	15.90	98
	3.5+4.2	3.91	4.69	-	-	2.34	8.60	9.47	0.43	2.76	3.48	2.00	12.20	15.40	98
	3.5+5.0	3.54	5.06	-	-	2.64	8.60	10.47	0.50	2.69	3.73	2.30	11.90	16.50	98
	3.5+6.0	3.17	5.43	-	-	2.78	8.60	10.56	0.52	2.56	3.59	2.40	11.40	15.90	98
	4.2+4.2	4.30	4.30	-	-	2.33	8.60	9.56	0.43	2.67	3.37	1.90	11.80	14.90	98
	4.2+5.0	3.93	4.67	-	-	2.63	8.60	10.54	0.49	2.58	3.61	2.30	11.50	16.00	98
	4.2+6.0	3.54	5.06	-	-	2.77	8.60	10.62	0.52	2.48	3.48	2.30	11.00	15.40	98
	5.0+5.0	4.30	4.30	-	-	3.08	8.60	10.59	0.59	2.51	3.53	2.70	11.20	15.70	98
	5.0+6.0	3.91	4.69	-	-	3.21	8.60	10.66	0.61	2.42	3.41	2.70	10.80	15.10	98
	1.5+1.5+1.5	1.83	1.83	1.83	-	2.31	5.50	9.92	0.42	1.24	3.14	1.90	5.60	14.00	98
	1.5+1.5+2.0	1.83	1.83	2.44	-	2.31	6.10	10.10	0.42	1.45	3.19	1.90	6.50	14.20	98
	1.5+1.5+2.5	1.83	1.83	3.05	-	2.31	6.70	10.18	0.42	1.64	3.18	1.90	7.30	14.20	98
	1.5+1.5+3.5	1.85	1.85	4.31	-	2.31	8.00	10.29	0.42	2.14	3.27	1.90	9.50	14.50	98
	1.5+1.5+4.2	1.79	1.79	5.02	-	2.45	8.60	10.29	0.44	2.33	3.16	2.00	10.40	14.00	98
	1.5+1.5+5.0	1.61	1.61	5.38	-	2.75	8.60	10.46	0.50	2.29	3.14	2.30	10.10	13.90	98
	1.5+1.5+6.0	1.43	1.43	5.73	-	3.03	8.60	10.59	0.55	2.22	3.07	2.50	9.80	13.60	98
	1.5+2.0+2.0	1.83	2.44	2.44	-	2.31	6.70	10.26	0.42	1.65	3.24	1.90	7.40	14.50	98
	1.5+2.0+2.5	1.83	2.43	3.04	-	2.31	7.30	10.36	0.42	1.87	3.26	1.90	8.30	14.50	98
	1.5+2.0+3.5	1.82	2.43	4.25	-	2.31	8.50	10.45	0.42	2.36	3.32	1.90	10.50	14.70	98
	1.5+2.0+4.2	1.68	2.23	4.69	-	2.45	8.60	10.46	0.44	2.33	3.22	2.00	10.40	14.30	98
	1.5+2.0+5.0	1.52	2.02	5.06	-	2.75	8.60	10.76	0.50	2.29	3.23	2.30	10.10	14.30	98
	1.5+2.0+6.0	1.36	1.81	5.43	-	3.03	8.60	10.80	0.55	2.22	3.13	2.50	9.80	13.90	98
	1.5+2.5+2.5	1.85	3.08	3.08	-	2.31	8.00	10.47	0.41	2.12	3.29	1.90	9.40	14.60	98
	1.5+2.5+3.5	1.72	2.87	4.01	-	2.46	8.60	10.58	0.44	2.38	3.32	2.00	10.60	14.70	98
	1.5+2.5+4.2	1.57	2.62	4.40	-	2.45	8.60	10.58	0.44	2.32	3.21	2.00	10.30	14.30	98
	1.5+2.5+5.0	1.43	2.39	4.78	-	2.89	8.60	10.77	0.53	2.27	3.20	2.40	10.10	14.20	98