

ATXB35C_ARXB35C

AFR	9,3
BF	0,25

Cooling 220-240V 50Hz

1	2	3																	
		20			25			30			32			35			40		
		TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
20	14	2,30	1,83	0,72	2,30	1,83	0,82	2,30	1,83	0,90	2,30	1,83	0,93	2,30	1,83	0,97	2,30	1,83	1,04
22	16	3,07	2,11	0,75	3,07	2,11	0,83	3,07	2,11	0,90	3,07	2,11	0,93	3,07	2,11	0,97	2,92	2,04	1,05
25	18	3,68	2,43	0,76	3,53	2,36	0,83	3,38	2,29	0,91	3,32	2,26	0,93	3,22	2,22	0,98	3,07	2,15	1,05
27	19	3,76	2,54	0,76	3,61	2,48	0,84	3,45	2,41	0,91	3,39	2,38	0,94	3,30	2,34	1,03	3,15	2,27	1,05
30	22	3,99	2,45	0,77	3,84	2,39	0,84	3,68	2,32	0,91	3,62	2,30	0,94	3,53	2,27	0,99	3,37	2,21	1,06
32	24	4,14	2,38	0,77	3,99	2,32	0,85	3,83	2,26	0,92	3,77	2,24	0,95	3,68	2,21	0,99	3,53	2,16	1,06

AFR	10,1
-----	------

Heating 220-240V 50Hz

1	4									
	-10		-5		0		6		10	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15	2,36	0,80	2,75	0,83	3,15	0,87	3,62	0,92	3,94	0,95
20	2,24	0,82	2,63	0,86	3,03	0,89	3,50	0,94	3,82	0,97
22	2,19	0,83	2,58	0,86	2,98	0,90	3,45	0,95	3,77	0,98
24	2,14	0,83	2,53	0,87	2,93	0,91	3,40	0,96	3,72	0,99
25	2,11	0,84	2,51	0,88	2,90	0,91	3,38	0,96	3,70	0,99
27	2,07	0,85	2,46	0,89	2,86	0,92	3,33	0,97	3,65	1,00

Symbols

TC Total capacity [kW]

PI: Power input [kW]

SHC: Sensible heat capacity [kW]

AFR: Air flow rate [m³/min]

BF: Bypass factor

- Indoor air temperature [°C DB]
- Indoor air temperature [°C WB]
- Outdoor air temperature [°C DB]
- Outdoor air temperature [°C WB]

Notes

- The capacities are based on the following conditions:
Corresponding refrigerant piping length: 5.0 m
Level difference: 0m
- The bold cells indicate the standard conditions.
Rated operating frequency [Hz]
- Editable data for this drawing are available in the GDE (E-BOM) system.