


ARXC20-25C


RXC20-25C



Testing Data Input								Overall (dBA)	Noise criteria
Fan speed	125	250	500	1k	2k	4k	8k		
H	49	47	43	40	33	28	21	45	39

NOTES

- Measuring place
Anechoic chamber
Operation noise differs with operation and ambient conditions.
- Operating conditions
Power source: 220-240V 50Hz
JIS: Standard
- Location of microphone.
JISC9612
The operation noise measuring method is in accordance with JISC9612.



3D121137A