



Cooling		Total dB
A	B	
dBA	46	

Heating		Total dB
A	B	
dBA	47	

**Notes**

- 1 Background noise already taken into account.
- 2 Operating conditions: power source 220-240 V/220 V 50/60 Hz; JIS standard
- 3 Operating noise varies depending on operation and ambient conditions.
- 4 The operation noise measuring method is in accordance with JISC9612.
- 5 Measuring location: anechoic chamber
- 6 Editable data for this drawing are available in the GDE (E-BOM) system.