


## HEATING



## NOTES

- Overall (dB)

Scale	50Hz 220V-240V 60Hz 220V-230V
A	49

(B,G,N is already rectified)

- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 220-240V/220-230V 50/60Hz  
○—○ 50/60Hz 220-240V/220-230V  
Heating
- Location of microphone  
JISC9612  
The operation noise measuring method is in accordance with JISC9612