


COOLING



NOTES

- 1 Overall (dB)

Scale	50Hz 230V
A	52

(B,G,N is already rectified)

- 2 Measuring place: Measure in anechoic room
 3 Operation noise differs with operation and ambient conditions.
 4 Operating conditions: Power source 230V 50Hz
 ○—○ 50Hz 230V
 Cooling

- 5 Location of microphone
-
- JISC9612

The operation noise measuring method is in accordance with JISC9612