


## HEATING



## NOTES

- 1 Overall (dB)

Scale	50Hz 230V
A	52

(B,G,N is already rectified)

- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 230V 50Hz  
 ○—○ 50Hz 230V  
 Heating
- Location of microphone  
 JISC9612  
 The operation noise measuring method is in accordance with JISC9612