


COOLING



NOTES

- 1 Overall (dB)

Scale	50Hz 220-240V
A	48

(B,G,N is already rectified)

- 2 Measuring place: Measure in anechoic room
- 3 Operation noise differs with operation and ambient conditions.
- 4 Operating conditions: Power source 220-240V 50Hz
 ○—○
 Cooling
- 5 Location of microphone

JISC9612

The operation noise measuring method is in accordance with JISC9612