

Cooling

50Hz 230V

AFR	8.7
BF	0.17

Indoor		Outdoor temp. (°CDB)																	
EWB (°C)	EDB (°C)	20			25			30			32			35			40		
		TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20	2.46	1.94	0.53	2.35	1.89	0.58	2.24	1.83	0.63	2.19	1.81	0.65	2.12	1.78	0.68	2.01	1.73	0.73
16.0	22	2.57	1.91	0.53	2.46	1.86	0.58	2.35	1.81	0.63	2.30	1.79	0.65	2.23	1.76	0.69	2.12	1.71	0.74
18.0	25	2.68	2.01	0.54	2.57	1.97	0.59	2.46	1.92	0.64	2.41	1.90	0.66	2.34	1.88	0.69	2.23	1.83	0.74
19.0	27	2.74	2.14	0.54	2.62	2.10	0.59	2.51	2.05	0.64	2.47	2.03	0.66	2.40	2.01	0.69	2.29	1.96	0.74
22.0	30	2.90	2.07	0.54	2.79	2.03	0.59	2.68	1.99	0.64	2.63	1.98	0.66	2.57	1.95	0.69	2.45	1.91	0.75
24.0	32	3.01	2.02	0.54	2.90	1.99	0.60	2.79	1.95	0.65	2.74	1.94	0.67	2.68	1.91	0.70	2.56	1.88	0.75

Heating

50Hz 230V

AFR	8.7
-----	-----

Indoor		Outdoor temp. (°CWB)									
EDB		-10		-5		0		6		10	
(°C)		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.15	0.77	2.52	0.81	2.88	0.84	3.31	0.89	3.60	0.92
20.0		2.04	0.79	2.41	0.83	2.77	0.87	3.20	0.91	3.49	0.94
22.0		2.00	0.80	2.36	0.84	2.72	0.87	3.16	0.92	3.44	0.95
24.0		1.96	0.81	2.32	0.84	2.68	0.88	3.11	0.93	3.40	0.96
25.0		1.93	0.81	2.29	0.85	2.66	0.89	3.09	0.93	3.38	0.96
27.0		1.89	0.82	2.25	0.86	2.61	0.89	3.05	0.94	3.33	0.97

3D081498

SYMBOLS

AFR:	Air flow rate	(m ³ /min)
BF:	Bypass factor	
EWB:	Entering wet bulb temp.	(°C)
EDB:	Entering dry bulb temp.	(°C)
TC:	Total capacity	(kW)
SHC:	Sensible heat capacity	(kW)
PI:	Power input	(kW)

NOTES

1. Ratings shown are net capacities which include a deduction for indoor fan motor heat.
2. shows nominal (rated) capacities and power input.
3. TC, PI and SHC must be calculated by interpolation using the figures in the above tables. (Figures out of the tables should not be used for calculation.)
4. About SHC which are not mentioned on the table, please calculate them with around values in direct proportion.
5. Capacities are based on the following conditions:
Corresponding refrigerant piping length: 7.5m
Level difference: 0m
6. Air flow rate (AFR) and Bypass factor (BF) are tabulated above table.