

Cooling50Hz 220-240V

AFR	12.00
BF	0.16

Indoor		Outdoor temp. (°CDB)																	
EWB	EDB	20			25			30			32			35			40		
(°C)	(°C)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14	20	5.06	3.73	1.26	4.90	3.66	1.34	4.74	3.59	1.42	4.68	3.55	1.46	4.59	3.51	1.51	4.43	3.44	1.59
16	22	5.23	3.77	1.28	5.07	3.69	1.36	4.91	3.62	1.45	4.85	3.60	1.47	4.76	3.54	1.53	4.60	3.47	1.61
18	25	5.39	3.81	1.30	5.23	3.73	1.39	5.07	3.66	1.46	5.01	3.63	1.50	4.91	3.59	1.55	4.76	3.51	1.63
19	27	5.48	3.82	1.32	5.32	3.74	1.40	5.16	3.67	1.48	5.10	3.65	1.51	5.00	3.60	1.56	4.84	3.52	1.65
22	30	5.72	3.88	1.34	5.56	3.81	1.43	5.40	3.73	1.51	5.34	3.70	1.54	5.24	3.66	1.59	5.09	3.59	1.67
24	32	5.89	3.91	1.37	5.73	3.84	1.46	5.57	3.77	1.53	5.51	3.73	1.57	5.41	3.69	1.62	5.26	3.62	1.70

Heating50Hz 220-240V

AFR	12.00
-----	-------

Indoor		Outdoor temp. (°CWB)															
EDB		-25		-20		-15		-10		-5		0		6		10	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
16		1.49	1.01	2.20	1.10	2.91	1.19	3.62	1.28	4.31	1.36	5.02	1.44	5.86	1.54	6.42	1.61
18		1.46	1.07	2.17	1.16	2.88	1.25	3.59	1.34	4.28	1.41	4.99	1.50	5.83	1.60	6.39	1.67
20		1.45	1.13	2.15	1.22	2.85	1.31	3.55	1.40	4.26	1.47	4.96	1.56	5.80	1.66	6.36	1.73
21		1.44	1.18	2.14	1.26	2.84	1.34	3.54	1.42	4.24	1.51	4.95	1.59	5.79	1.69	6.35	1.75
22		1.45	1.19	2.14	1.28	2.83	1.37	3.52	1.46	4.23	1.53	4.92	1.62	5.77	1.72	6.33	1.79
24		1.37	1.25	2.08	1.34	2.79	1.43	3.50	1.52	4.20	1.60	4.90	1.68	5.75	1.78	6.31	1.85

3D083666

SYMBOLS

AFR:	Air flow rate	(m ³ /min)
BF:	Bypass factor	
EWB:	Entering wet bulb temp.	(°C)
EDB:	Entering dry bulb temp.	(°C)
TC:	Total capacity	(kW)
SHC:	Sensible heat capacity	(kW)
PI:	Power input	(kW)

NOTES

1. shows nominal (rated) capacities and power input.
2. Capacities are based on the following conditions:
Corresponding refrigerant piping length: 5.0m
Level difference: 0m