

Cooling

50Hz 230V

AFR	17
BF	0.2

Indoor		Outdoor temperature (°CDB)																	
EWB	EDB	20			25			30			32			35			40		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20	5.84	4.25	1.65	5.57	4.12	1.81	5.31	3.98	1.97	5.20	3.93	2.03	5.04	3.85	2.13	4.78	3.72	2.29
16.0	22	6.10	4.18	1.66	5.84	4.05	1.82	5.57	3.93	1.98	5.47	3.88	2.04	5.31	3.80	2.14	5.04	3.68	2.29
18.0	25	6.36	4.36	1.67	6.10	4.25	1.83	5.83	4.13	1.99	5.73	4.08	2.05	5.57	4.01	2.15	5.30	3.90	2.30
19.0	27	6.50	4.59	1.67	6.23	4.48	1.83	5.97	4.36	1.99	5.86	4.32	2.05	5.70	4.25	2.15	5.43	4.14	2.31
22.0	30	6.89	4.42	1.69	6.62	4.32	1.85	6.36	4.22	2.01	6.25	4.18	2.07	6.09	4.12	2.16	5.83	4.03	2.32
24.0	32	7.15	4.30	1.70	6.89	4.21	1.86	6.62	4.12	2.01	6.52	4.08	2.08	6.36	4.03	2.17	6.09	3.94	2.33

Heating

50Hz 230V

AFR	16
-----	----

Indoor		Outdoor temperature (°CWB)											
EWB		-15		-10		-5		0		6		10	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.03	2.00	4.85	2.11	5.66	2.21	6.47	2.31	7.45	2.43	8.10	2.52
20.0		3.79	2.06	4.60	2.16	5.41	2.26	6.22	2.37	7.20	2.49	7.85	2.57
22.0		3.69	2.08	4.50	2.18	5.31	2.29	6.12	2.39	7.10	2.51	7.75	2.59
24.0		3.59	2.10	4.40	2.21	5.21	2.31	6.03	2.41	7.00	2.53	7.51	2.62
25.0		3.54	2.12	4.35	2.22	5.16	2.32	5.98	2.42	6.95	2.55	7.28	2.63
27.0		3.44	2.14	4.25	2.24	5.06	2.34	5.88	2.45	6.81	2.57	6.81	2.65

3D075749

SYMBOLS

AFR:	Air flow rate	(m ³ /min.)
BF:	Bypass factor	
EWB:	Entering wet bulb temp.	(°C)
EDB:	Entering dry bulb temp.	(°C)
TC:	Total capacity	(kW)
SHC:	Sensible heat capacity	(kW)
PI:	Power input	(kW)

NOTES

1. shows nominal (rated) capacities and power input.
2. TC, PI and SHC must be calculated by interpolation using the figures in the above tables. (Figures out of the tables should not be used for calculation.)
3. Capacities are based on the following conditions:
 - (1) Corresponding refrigerant piping length: 7.5m
 - (2) Level difference: 1m