


COOLING




NOTES

- 1 Overall (dB)

Scale	50Hz 230V (H) (H)	50Hz 230V (L) (L)
A	48	41

(B,G,N is already rectified)

- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 230V 50Hz
JIS Standard
- Standard external static pressure
 ○—○ 50 Hz 230V (H)
 ○---○ 50 Hz 230V (L)
 Cooling
- Location of microphone
JISC9612



The operation noise measuring method is in accordance with JISC9612