





NOTES

- 1 Over All (dB):
(B,G,N is already rectified)
- 2 Measuring place: measure in anechoic room.
- 3 Operation noise differs with operation and ambient conditions.
- 4 Location of microphone.

JISC9612

The operation noise measuring method is in accordance with JISC9612



Scale	50Hz 230V	
	H	L
A	40	28