
**NOTES**

- Over All (dB):
(B, G, N is already rectified)
- Measuring place: measure in anechoic room.
- Operation noise differs with operation and ambient conditions.
- Location of microphone.
JISC9612

The operation noise measuring method is in accordance with JISC9612




Scale	50Hz 220-240V	
	H	L
A	45	36

NOTES

- Over All (dB):
(B, G, N is already rectified)
- Measuring place: measure in anechoic room.
- Operation noise differs with operation and ambient conditions.
- Location of microphone.
JISC9612

The operation noise measuring method is in accordance with JISC9612



Scale	50Hz 220-240V	
	H	L
A	44	35