



## NOTES

### 1 Overall (dB)

| Scale | 50Hz<br>220-240V (H) | 50Hz<br>220-240V (L) |
|-------|----------------------|----------------------|
| A     | 46                   | 34                   |

(B,G,N is already rectified)

- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 220-240V 50Hz
- Standard external static pressure
- 50 Hz 220-240V (H)  
 ○---○ 50 Hz 220-240V (L)  
 Cooling
- Location of microphone  
JISC9612

The operation noise measuring method is in accordance with JISC9612

