

Cooling50Hz 220-240V

AFR	10.7
BF	0.13

Indoor		Outdoor temp. (°CDB)																	
EWB	EDB	20			25			30			32			35			40		
(°C)	(°C)	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20	4.53	3.19	1.13	4.53	3.19	1.27	4.53	3.19	1.41	4.53	3.19	1.46	4.42	3.13	1.53	4.19	3.01	1.65
16.0	22	5.35	3.45	1.20	5.12	3.33	1.31	4.89	3.21	1.43	4.79	3.16	1.47	4.65	3.09	1.54	4.42	2.98	1.65
18.0	25	5.58	3.56	1.20	5.35	3.45	1.32	5.12	3.34	1.43	5.02	3.29	1.48	4.88	3.23	1.55	4.65	3.12	1.66
19.0	27	5.70	3.71	1.21	5.47	3.60	1.32	5.23	3.49	1.44	5.14	3.45	1.48	5.00	3.39	1.55	4.77	3.28	1.66
22.0	30	6.04	3.56	1.22	5.81	3.46	1.33	5.58	3.37	1.45	5.49	3.33	1.49	5.35	3.27	1.56	5.11	3.18	1.67
24.0	32	6.27	3.45	1.22	6.04	3.36	1.34	5.81	3.27	1.45	5.72	3.24	1.50	5.58	3.19	1.57	5.34	3.10	1.68

Heating50Hz 220-240V

AFR	11.8
-----	------

Indoor		Outdoor temp. (°CWB)									
EDB		-10		-5		0		6		10	
(°C)		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		3.90	1.35	4.56	1.42	5.21	1.48	6.00	1.56	6.52	1.62
20.0		3.70	1.39	4.36	1.46	5.01	1.52	5.80	1.60	6.32	1.65
22.0		3.62	1.40	4.28	1.47	4.93	1.54	5.72	1.61	6.24	1.67
24.0		3.54	1.42	4.20	1.48	4.85	1.55	5.64	1.63	6.16	1.68
25.0		3.50	1.43	4.16	1.49	4.81	1.56	5.60	1.64	6.03	1.68
27.0		3.42	1.44	4.08	1.51	4.73	1.57	5.52	1.65	5.64	1.68

3D079452A

SYMBOLS

AFR:

Air flow rate

(m³/min)

BF:

Bypass factor

EWB:

Entering wet bulb temp.

(°C)

EDB:

Entering dry bulb temp.

(°C)

TC:

Total capacity

(kW)

SHC:

Sensible heat capacity

(kW)

PI:

Power input

(kW)

NOTES

1. Capacities are based on the following conditions:

(1) Corresponding refrigerant piping length: 5.0m

(2) Level difference: 0m

2. shows nominal (rated) capacities and power input.