




NOTES

1 Overall (dB)

Scale	50Hz 220~240V (H)
A	46

(B,G,N is already rectified)

2 Measuring place: Measure in anechoic room

3 Operation noise differs with operation and ambient conditions.



4 Operating conditions:
Power source 220~240V 50Hz

O—O Cooling

5 Location of microphone

JISC9612

The operation noise measuring method is in accordance with JISC9612



NOTES

1 Overall (dB)

Scale	50Hz 220~240V (H)
A	47

(B,G,N is already rectified)

2 Measuring place: Measure in anechoic room

3 Operation noise differs with operation and ambient conditions.

4 Operating conditions:
Power source 220~240V 50Hz

O—O Heating

5 Location of microphone

JISC9612

The operation noise measuring method is in accordance with JISC9612

