


COOLING



NOTES

- Overall (dB)

Scale	50Hz 220~240V (H)
A	48

(B,G,N is already rectified)

- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 220~240V 50Hz
○—○
Cooling
- Location of microphone
JISC9612
The operation noise measuring method is in accordance with JISC9612

