






NOTES

- Overall (dB)
(B,G,N is already rectified)
- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 220~240V 50Hz
- Location of microphone
JISC9612
The operation noise measuring method is in accordance with JISC9612




Scale	50Hz 220~240V (H)
A	48

○ — ○ Cooling



NOTES

- Overall (dB)
(B,G,N is already rectified)
- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 220~240V 50Hz
- Location of microphone
JISC9612
The operation noise measuring method is in accordance with JISC9612



Scale	50Hz 220~240V (H)
A	48

○ — ○ Heating