


HEATING



NOTES

- Overall (dB)

Scale	50Hz 220-240V
A	48

(B,G,N is already rectified)

- Measuring place: Measure in anechoic room
- Operation noise differs with operation and ambient conditions.
- Operating conditions: Power source 220-240V 50Hz
○—○ 50Hz 220-240V
Heating
- Location of microphone
JISC9612
The operation noise measuring method is in accordance with JISC9612