

Cooling 50Hz 220-240V

AFR	13.5
BF	0.21

Indoor		Outdoor temperature (°C DB)																	
EWB °C	EDB °C	20			25			30			32			35			40		
		TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20	5.84	4.01	1.26	5.57	3.86	1.38	5.31	3.72	1.50	5.20	3.66	1.55	5.04	3.58	1.62	4.78	3.44	1.74
16.0	22	6.10	3.94	1.27	5.84	3.80	1.39	5.57	3.67	1.51	5.47	3.61	1.56	5.31	3.53	1.63	5.04	3.40	1.75
18.0	25	6.36	4.07	1.27	6.10	3.94	1.39	5.83	3.81	1.52	5.73	3.76	1.56	5.57	3.69	1.64	5.30	3.56	1.76
19.0	27	6.50	4.24	1.28	6.23	4.11	1.40	5.97	3.99	1.52	5.86	3.94	1.57	5.70	3.87	1.64	5.43	3.75	1.76
22.0	30	6.89	4.07	1.29	6.62	3.95	1.41	6.36	3.85	1.53	6.25	3.80	1.58	6.09	3.74	1.65	5.83	3.63	1.77
24.0	32	7.15	3.94	1.29	6.89	3.84	1.42	6.62	3.74	1.54	6.52	3.70	1.59	6.36	3.64	1.66	6.09	3.54	1.78

Heating 50Hz 220-240V

AFR	13.5
-----	------

Indoor		Outdoor temperature (°C WB)									
EDB	°C	-10		-5		0		6		10	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0	4.71	1.68	5.50	1.76	6.29	1.85	7.24	1.95	7.87	2.01	
20.0	4.47	1.73	5.26	1.81	6.05	1.89	7.00	1.99	7.63	2.06	
22.0	4.37	1.75	5.16	1.83	5.95	1.91	6.90	2.01	7.54	2.07	
24.0	4.28	1.76	5.07	1.85	5.86	1.93	6.81	2.03	7.12	2.09	
25.0	4.23	1.77	5.02	1.85	5.81	1.94	6.76	2.03	6.90	2.10	
27.0	4.13	1.79	4.92	1.87	5.71	1.95	6.45	2.05	6.45	2.11	

SYMBOLS

- AFR : Air flow rate (m³/min.)
- BF : Bypass factor
- EWB : Entering wet bulb temp. (°C)
- EDB : Entering dry bulb temp. (°C)
- TC : Total capacity (kW)
- SHC : Sensible heat capacity (kW)
- PI : Power input (kW)

NOTES

1. Capacities are based on the following conditions.
(1) Corresponding refrigerant piping length : 5m
(2) Level difference : 0m
2. shows nominal (rated) capacities and power input.