

FTXJ25MW / RXJ25M9
FTXJ25MS / RXJ25M9

Cooling ·220-240V 50Hz·

AFR	8,9
BF	0,07

1	2	3																	
		20			25			30			32			35			40		
		TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
20	14	2,46	2,05	0,39	2,35	2,00	0,43	2,24	1,95	0,47	2,19	1,93	0,48	2,12	1,90	0,50	2,01	1,85	0,54
22	16	2,57	2,02	0,39	2,46	1,97	0,43	2,35	1,92	0,47	2,30	1,90	0,48	2,23	1,87	0,51	2,12	1,82	0,54
25	18	2,68	2,15	0,40	2,57	2,10	0,43	2,46	2,06	0,47	2,41	2,04	0,49	2,34	2,01	0,51	2,23	1,97	0,55
27	19	2,74	2,29	0,40	2,62	2,25	0,43	2,51	2,21	0,47	2,47	2,19	0,49	2,40	2,16	0,51	2,29	2,12	0,55
30	22	2,90	2,22	0,40	2,79	2,18	0,44	2,68	2,15	0,48	2,63	2,13	0,49	2,57	2,11	0,51	2,45	2,07	0,55
32	24	3,01	2,17	0,40	2,90	2,14	0,44	2,79	2,10	0,48	2,74	2,09	0,49	2,68	2,07	0,52	2,56	2,04	0,55

Heating ·220-240V 50Hz·

AFR	11
-----	----

1	4									
	-10		-5		0		6		10	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15	2,15	0,59	2,52	0,62	2,88	0,65	3,31	0,68	3,60	0,71
20	2,04	0,61	2,41	0,64	2,77	0,67	3,20	0,70	3,49	0,72
22	2,00	0,61	2,36	0,64	2,72	0,67	3,16	0,71	3,44	0,73
24	1,96	0,62	2,32	0,65	2,68	0,68	3,11	0,71	3,40	0,74
25	1,93	0,62	2,29	0,65	2,66	0,68	3,09	0,72	3,38	0,74
27	1,89	0,63	2,25	0,66	2,61	0,69	3,05	0,72	3,33	0,75

Symbols

- TC: Total capacity [kW]
- PI: Power input [kW]
- SHC: Sensible heat capacity [kW]
- AFR: Air flow rate [m³/min]
- BF: Bypass factor [°C WB]

- 1 Indoor air temperature [°C DB]
- 2 Indoor air temperature [°C WB]
- 3 Outdoor air temperature [°C DB]
- 4 Outdoor air temperature

Notes

- 1. The capacities are based on the following conditions:
Corresponding refrigerant piping length: ·5.0· m
Level difference: ·0·m
- 2. The bold cells indicate the standard conditions.
Rated operating frequency [Hz]