

Cooling

50Hz 220 -240V

| | |
|-----|-------|
| AFR | 10,48 |
| BF | 0,08 |

| Indoor air temperature [° C WB] | Indoor air temperature [° C DB] | Outdoor temperature [° C DB] | | | | | | | | | | | | | | | | | |
|------------------------------------|------------------------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| | | 20 | | | 25 | | | 30 | | | 32 | | | 35 | | | 40 | | |
| °C | °C | TC | SHC | PI | TC | SHC | PI | TC | SHC | PI | TC | SHC | PI | TC | SHC | PI | TC | SHC | PI |
| 14 | 20 | 2,05 | 2,05 | 0,34 | 1,96 | 1,96 | 0,37 | 1,86 | 1,86 | 0,40 | 1,83 | 1,83 | 0,41 | 1,77 | 1,77 | 0,43 | 1,68 | 1,68 | 0,47 |
| 16 | 22 | 2,14 | 1,95 | 0,34 | 2,05 | 1,98 | 0,37 | 1,95 | 1,95 | 0,40 | 1,92 | 1,92 | 0,42 | 1,86 | 1,86 | 0,43 | 1,77 | 1,77 | 0,47 |
| 18 | 25 | 2,23 | 2,23 | 0,34 | 2,14 | 2,14 | 0,37 | 2,05 | 2,05 | 0,40 | 2,01 | 2,01 | 0,42 | 1,95 | 1,95 | 0,44 | 1,86 | 1,86 | 0,47 |
| 19 | 27 | 2,28 | 2,28 | 0,34 | 2,19 | 2,19 | 0,37 | 2,09 | 2,09 | 0,41 | 2,06 | 2,06 | 0,42 | 2,00 | 2,00 | 0,44 | 1,91 | 1,91 | 0,47 |
| 22 | 30 | 2,42 | 2,32 | 0,34 | 2,32 | 2,32 | 0,38 | 2,23 | 2,23 | 0,41 | 2,19 | 2,19 | 0,42 | 2,14 | 2,14 | 0,44 | 2,05 | 2,05 | 0,47 |
| 24 | 32 | 2,51 | 2,07 | 0,35 | 2,42 | 2,14 | 0,38 | 2,32 | 2,25 | 0,41 | 2,29 | 2,29 | 0,42 | 2,23 | 2,23 | 0,44 | 2,14 | 2,14 | 0,47 |

Heating

50Hz 220 -240V

| | |
|-----|------|
| AFR | 9,33 |
|-----|------|

| Indoor air temperature [° C DB] | Outdoor temperature [° C WB] | | | | | | | | | | | |
|------------------------------------|------------------------------|------|------|------|------|------|------|------|------|------|------|------|
| | -15 | | -10 | | -5 | | 0 | | 7 | | 10 | |
| °C | TC | PI | TC | PI | TC | PI | TC | PI | TC | PI | TC | PI |
| 15 | 1,19 | 0,32 | 1,43 | 0,34 | 1,67 | 0,36 | 1,94 | 0,46 | 2,59 | 0,49 | 2,81 | 0,51 |
| 20 | 1,12 | 0,33 | 1,36 | 0,35 | 1,60 | 0,37 | 1,86 | 0,47 | 2,50 | 0,50 | 2,73 | 0,52 |
| 22 | 1,09 | 0,34 | 1,33 | 0,36 | 1,57 | 0,37 | 1,83 | 0,48 | 2,47 | 0,50 | 2,69 | 0,52 |
| 24 | 1,06 | 0,34 | 1,30 | 0,36 | 1,54 | 0,38 | 1,80 | 0,48 | 2,43 | 0,51 | 2,66 | 0,53 |
| 25 | 1,04 | 0,34 | 1,28 | 0,36 | 1,52 | 0,38 | 1,78 | 0,49 | 2,41 | 0,51 | 2,64 | 0,53 |
| 27 | 1,01 | 0,35 | 1,25 | 0,37 | 1,49 | 0,38 | 1,76 | 0,49 | 2,38 | 0,52 | 2,61 | 0,54 |

Symbols

AFR: Air flow rate [m³/min]

BF: Bypass factor

TC: Total capacity [kW]

SHC: Sensible heat capacity [kW]

PI: Power input [kW]

Notes

- The ratings shown are net capacities which include a deduction for indoor fan motor heat.
- Nominal capacity and nominal input
- The total capacity, power input and sensible heat capacity must be calculated by interpolation, using the figures in the table (figures not in the table may not be used in the calculation).
- In case the sensible heat capacity is not mentioned in the table, please calculate it using an approximation between two values in direct proportion.
- The capacities are based on the following conditions:
Corresponding refrigerant piping length: ·5· m
Level difference: ·0·m
- The air flow rate and bypass factor are mentioned in the table.