ARXM71A

RXM69-71A

RXM50A9

Unit combination restrictions		Power supply					COMP		OFM		IFM	
Outdoor unit	Indoor unit	Hz	Voltage	Voltage range	MCA	MFA	RHz	RLA	kW	FLA	kW	FLA
RXM50A5V1B9	FVXM50B2V1B	50	220	MAX. 50Hz 264V MIN. 50Hz 198V	14,54	16	58	5,3	0,066	0,83	0,037	0,14
		50	230					5,1				
		50	240					4,9				
ARXM71A5V1B	FHA71AVEB9	50	220	MAX. 50Hz 264V MIN. 50Hz 198V	15,81	16	83	8,3	0,066	0,83	0,110	0,80
		50	230					7,9				
		50	240					7,6				
ARXM71A5V1B	FHA71AVEB99	50	220	MAX. 50Hz 264V MIN. 50Hz 198V	15,81	16	83	8,3	0,066	0,83	0,110	0,80
		50	230					7,9				
		50	240					7,6				
ARXM71A5V1B	FHA71AVEB98	50	220	MAX. 50Hz 264V MIN. 50Hz 198V	15,81	16	83	8,3	0,066	0,83	0,110	0,80
		50	230					7,9				
		50	240					7,6				
RXM60A5V1B	FTXM60B2V1B	50	220	MAX. 50Hz 264V MIN. 50Hz 198V	15,59	16	70	6,6	0,066	0,83	0,046	0,60
		50	230					6,3				
		50	240					6,0				
RXM71A5V1B	FTXM71B2V1B	50	220	MAX. 50Hz 264V MIN. 50Hz 198V	19,91	20	54	9,4	0,090	1,00	0,052	0,60
		50	230					8,9				
		50	240					8,6				

MCA: Minimum Circuit Amperes [A]
MFA: Maximum Fuse Amperes [A]
COMP: Compressor
RHz: Rated operating frequency [Hz]
RLA: Rated Load Amperes [A]
OFM: Outdoor fan motor
IFM: Indoor fan motor
kW: Fan motor rated output [kW]
FLA: Full Load Amperes [A]
MAX.: Maximum
MIN.: Minimum

1) The ·RLA· is based on the following conditions.
Outdoor temperature ·35·°C DB
Indoor temperature ·27·°C DB / ·19·°C WB
2) Select the wire size according to the MCA.
3) The maximum allowable voltage that is unbalanced between phases is ·2·%.
4) Use a circuit breaker instead of a fuse.