



NOTES

1. No drain treatment necessary.
2. This unit can be installed so that F or R side faces forward. (it choosed by servicing direction).
3. The piping for the indoor unit and outdoor unit can be freely installed to directions of A, B, C or D.
4. This unit can be installed with either suspending from the ceiling or mounting on wall.

CAUTIONS

1. This unit must be installed so that side of E is facing up.
2. The slant of face E must be within $\pm 5^\circ$ for front and rear, right and left.
3. Before mounting on the wall, installation becomes easy by hanging this unit on screw for temporary fixing. (2 places)
4. At the time of brazing the pipes, wrap the pipes with sufficient wet clothes. And after brazing also, must cool piping enough.
5. Cut the piping of the standard accessories in order to match the indoor unit's piping diameter.

