

			Indoor air temp.													
Unit Size	Nominal Capacity	Outdoor °CDB	14.0 WB		16.0 WB		18.0 WB		19.0 WB		20.0 WB		22.0 WB		24.0 WB	
			20.0 DB		23.0 DB		26.0 DB		27.0 DB		28.0 DB		30.0 DB		32.0 DB	
			TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
40	4.5	10.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.4	3.4	5.9	3.5
		12.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.4	3.4	5.8	3.4
		14.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.4	3.4	5.8	3.4
		16.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.4	3.4	5.7	3.4
		18.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.4	3.4	5.6	3.3
		20.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.4	3.4	5.5	3.3
		21.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.4	3.4	5.5	3.3
		23.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.3	3.3	5.4	3.2
		25.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.2	3.3	5.3	3.2
		27.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.2	3.3	5.3	3.2
		29.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.1	3.2	5.2	3.1
		31.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	5.0	3.2	.5.1	3.1
		33.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.8	3.3	4.9	3.2	5.0	3.1
		35.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.3	4.7	3.3	4.9	3.1	5.0	3.0
		37.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.2	4.7	3.2	4.8	3.1	4.9	3.0
50	5.6	39.0	3.0	2.5	3.6	2.9	4.2	3.2	4.5	3.2	4.6	3.2	4.7	3.1	4.8	3.0
		10.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.7	4.4	7.4	4.4
		12.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.7	4.4	7.3	4.4
		14.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.7	4.4	7.2	4.3
		16.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.7	4.4	7.1	4.3
		18.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.7	4.4	7.0	4.2
		20.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.7	4.4	6.9	4.2
		21.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.7	4.4	6.8	4.2
		23.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.6	4.3	6.7	4.1
		25.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.5	4.3	6.6	4.1
		27.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.4	4.2	6.6	4.0
		29.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.3	4.2	6.5	4.0
		31.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.2	4.1	6.4	4.0
		33.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	6.0	4.2	6.1	4.1	6.3	3.9
		35.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	5.9	4.2	6.0	4.0	6.2	3.9
		37.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	5.8	4.1	5.9	4.0	6.1	3.8
		39.0	3.8	3.1	4.5	3.6	5.2	4.0	5.6	4.1	5.7	4.1	5.8	3.9	6.0	3.8