

Unit Size	Nominal Capacity	Outdoor air temp.		Indoor air temp.: °CDB					
				16.0	18.0	20.0	21.0	22.0	24.0
		°CDB	°CWB	kW	kW	kW	kW	kW	kW
15	1.9	-19.8	-20.0	1.1	1.1	1.1	1.1	1.1	1.1
		-18.8	-19.0	1.2	1.2	1.1	1.1	1.1	1.1
		-16.7	-17.0	1.2	1.2	1.2	1.2	1.2	1.2
		-14.7	-15.0	1.3	1.3	1.3	1.3	1.3	1.3
		-12.6	-13.0	1.4	1.4	1.4	1.3	1.3	1.3
		-10.5	-11.0	1.4	1.4	1.4	1.4	1.4	1.4
		-9.5	-10.0	1.5	1.5	1.5	1.4	1.4	1.4
		-8.5	-9.1	1.5	1.5	1.5	1.5	1.5	1.5
		-7.0	-7.6	1.5	1.5	1.5	1.5	1.5	1.5
		-5.0	-5.6	1.6	1.6	1.6	1.6	1.6	1.6
		-3.0	-3.7	1.7	1.7	1.7	1.7	1.7	1.7
		0.0	-0.7	1.8	1.8	1.8	1.8	1.8	1.7
		3.0	2.2	1.9	1.9	1.9	1.8	1.8	1.7
		5.0	4.1	1.9	1.9	1.9	1.8	1.8	1.7
		7.0	6.0	2.0	2.0	1.9	1.8	1.8	1.7
		9.0	7.9	2.1	2.0	1.9	1.8	1.8	1.7
		11.0	9.8	2.1	2.0	1.9	1.8	1.8	1.7
		13.0	11.8	2.1	2.0	1.9	1.8	1.8	1.7
		15.0	13.7	2.1	2.0	1.9	1.8	1.8	1.7
20	2.5	-19.8	-20.0	1.5	1.5	1.5	1.5	1.5	1.5
		-18.8	-19.0	1.5	1.5	1.5	1.5	1.5	1.5
		-16.7	-17.0	1.6	1.6	1.6	1.6	1.6	1.6
		-14.7	-15.0	1.7	1.7	1.7	1.7	1.7	1.7
		-12.6	-13.0	1.8	1.8	1.8	1.8	1.8	1.8
		-10.5	-11.0	1.9	1.9	1.9	1.9	1.9	1.9
		-9.5	-10.0	1.9	1.9	1.9	1.9	1.9	1.9
		-8.5	-9.1	2.0	2.0	1.9	1.9	1.9	1.9
		-7.0	-7.6	2.0	2.0	2.0	2.0	2.0	2.0
		-5.0	-5.6	2.1	2.1	2.1	2.1	2.1	2.1
		-3.0	-3.7	2.2	2.2	2.2	2.2	2.2	2.2
		0.0	-0.7	2.3	2.3	2.3	2.3	2.3	2.2
		3.0	2.2	2.5	2.5	2.4	2.4	2.3	2.2
		5.0	4.1	2.5	2.5	2.5	2.4	2.3	2.2
		7.0	6.0	2.6	2.6	2.5	2.4	2.3	2.2
		9.0	7.9	2.7	2.7	2.5	2.4	2.3	2.2
		11.0	9.8	2.8	2.7	2.5	2.4	2.3	2.2
		13.0	11.8	2.8	2.7	2.5	2.4	2.3	2.2
		15.0	13.7	2.8	2.7	2.5	2.4	2.3	2.2
25	3.2	-19.8	-20.0	1.9	1.9	1.9	1.9	1.9	1.9
		-18.8	-19.0	1.9	1.9	1.9	1.9	1.9	1.9
		-16.7	-17.0	2.1	2.1	2.0	2.0	2.0	2.0
		-14.7	-15.0	2.2	2.2	2.2	2.2	2.2	2.1
		-12.6	-13.0	2.3	2.3	2.3	2.3	2.3	2.3
		-10.5	-11.0	2.4	2.4	2.4	2.4	2.4	2.4
		-9.5	-10.0	2.5	2.4	2.4	2.4	2.4	2.4
		-8.5	-9.1	2.5	2.5	2.5	2.5	2.5	2.5
		-7.0	-7.6	2.6	2.6	2.6	2.6	2.6	2.6
		-5.0	-5.6	2.7	2.7	2.7	2.7	2.7	2.7
		-3.0	-3.7	2.8	2.8	2.8	2.8	2.8	2.8
		0.0	-0.7	3.0	3.0	3.0	3.0	3.0	2.8
		3.0	2.2	3.1	3.1	3.1	3.1	3.0	2.8
		5.0	4.1	3.3	3.2	3.2	3.1	3.0	2.8
		7.0	6.0	3.4	3.4	3.2	3.1	3.0	2.8
		9.0	7.9	3.5	3.4	3.2	3.1	3.0	2.8
		11.0	9.8	3.6	3.4	3.2	3.1	3.0	2.8
		13.0	11.8	3.6	3.4	3.2	3.1	3.0	2.8
		15.0	13.7	3.6	3.4	3.2	3.1	3.0	2.8
32	4.0	-19.8	-20.0	2.4	2.4	2.3	2.3	2.3	2.3
		-18.8	-19.0	2.4	2.4	2.4	2.4	2.4	2.4
		-16.7	-17.0	2.6	2.6	2.6	2.6	2.6	2.5
		-14.7	-15.0	2.7	2.7	2.7	2.7	2.7	2.7
		-12.6	-13.0	2.9	2.8	2.8	2.8	2.8	2.8
		-10.5	-11.0	3.0	3.0	3.0	3.0	3.0	3.0
		-9.5	-10.0	3.1	3.1	3.1	3.1	3.0	3.0
		-8.5	-9.1	3.1	3.1	3.1	3.1	3.1	3.1
		-7.0	-7.6	3.2	3.2	3.2	3.2	3.2	3.2
		-5.0	-5.6	3.4	3.4	3.4	3.4	3.4	3.4
		-3.0	-3.7	3.5	3.5	3.5	3.5	3.5	3.5
		0.0	-0.7	3.7	3.7	3.7	3.7	3.7	3.5
		3.0	2.2	3.9	3.9	3.9	3.9	3.7	3.5
		5.0	4.1	4.1	4.1	4.0	3.9	3.7	3.5
		7.0	6.0	4.2	4.2	4.0	3.9	3.7	3.5
		9.0	7.9	4.3	4.3	4.0	3.9	3.7	3.5
		11.0	9.8	4.5	4.3	4.0	3.9	3.7	3.5
		13.0	11.8	4.5	4.3	4.0	3.9	3.7	3.5
		15.0	13.7	4.5	4.3	4.0	3.9	3.7	3.5