
REYQ10P8



4D058295A

NOTE

Scale	50Hz
A	58
C	66

1 Over All (dB):
(B, G, N is already rectified)

2 Operating conditons:
- Power source Y1: 380-415V 50Hz
- JIS standard

3 Measuring place: Anechoic chamber (conversion value)
The operating sound is measured in anechoic chamber, if it is measured under the actual installation conditions, it is normally over the set value due to environmental noise and sound reflection.

4 Location of microphone

