
REYQ8P9



4D058294A

NOTE

1 Over All (dB):
(B, G, N is already rectified)


Scale	50Hz
A	58
C	66

2 Operating conditons:

- Power source: Y1: 380-415V 50Hz
- JIS Standard

3 Measuring place: Anechoic chamber (Conversion value)

4 Location of microphone



5 The operating sound is measured in anechoic chamber.
If it is measured under the actual istallation conditions, it is normally over the set value due to enviromental noise and sound reflection.