


## HEAT PUMP OPERATION



## NOTES

- Cooling operation range is kept in any case
- This figure shows the range which can be operated when the water flow is between 50~150 l/min.
- Design within the following condition range:  
water temperature: 20 ~ 35 °C  
water volume: 60 l/min or more
- When cooling load is small, thermostat-off may be carried out for freeze-up protection
- Hold ambient temperature at 0~40°C and humidity at 80%RH or less.