


4D061975

NOTE

- 1 Over All (dB):
(B, G, N is already rectified)
- 2 Operating conditons:
 - Power source: Y1K : 380-415V 50Hz
 - JIS Standard
- 3 Measuring place: Anechoic chamber (Conversion value)
- 4 Location of microphone

Scale	60Hz
A	65.0
C	73.0



- 5 The operating sound is measured in an anechoic chamber.
If it is measured under the actual installation conditions, it is normally over the set value due to environmental noise and sound reflection.