

Te = 6°C															
Indoor air temp. °CWB															
Combination(%) (Capacity index)	Outdoor air temp. (°CDB)	14.0		16.0		18.0		19.0		20.0		22.0		24.0	
		TC KW	PI KW	TC KW	PI KW	TC KW	PI KW	TC KW	PI KW	TC KW	PI KW	TC KW	PI KW	TC KW	PI KW
130%	10	53.9	7.80	67.4	9.88	80.9	12.1	84.9	12.5	86.1	12.2	88.7	11.6	91.2	10.9
	12	53.9	7.93	67.4	10.1	80.9	12.3	83.8	12.4	85.1	12.1	87.6	11.5	90.1	11.5
	14	53.9	8.07	67.4	10.2	80.9	12.5	82.7	12.3	84.0	12.0	86.5	12.0	89.0	12.1
	16	53.9	8.21	67.4	10.4	80.3	12.6	81.6	12.4	82.9	12.5	85.4	12.7	87.9	12.8
	18	53.9	8.36	67.4	10.6	79.2	13.0	80.5	13.1	81.8	13.2	84.3	13.3	86.8	13.5
	20	53.9	8.51	67.4	11.1	78.1	13.6	79.4	13.7	80.7	13.8	83.2	14.0	85.7	14.1
	21	53.9	8.59	67.4	11.5	77.6	14.0	78.9	14.0	80.1	14.1	82.6	14.3	85.2	14.5
	23	53.9	9.13	67.4	12.3	76.5	14.6	77.8	14.7	79.0	14.8	81.5	14.9	84.1	15.1
	25	53.9	9.74	67.4	13.2	75.4	15.2	76.7	15.3	77.9	15.4	80.4	15.6	83.0	15.8
	27	53.9	10.4	67.4	14.1	74.3	15.9	75.6	16.0	76.8	16.1	79.4	16.3	81.9	16.5
	29	53.9	11.1	67.4	15.0	73.2	16.5	74.5	16.6	75.7	16.7	78.3	16.9	80.8	17.1
	31	53.9	11.8	67.4	16.0	72.1	17.2	73.4	17.3	74.6	17.4	77.2	17.6	79.7	17.8
	33	53.9	12.5	67.4	17.1	71.0	17.8	72.3	17.9	73.5	18.0	76.1	18.3	78.6	18.5
	35	53.9	13.3	67.4	18.2	69.9	18.5	71.2	18.6	72.4	18.7	75.0	19.0	77.5	19.2
	37	53.9	14.1	66.3	18.9	68.8	19.1	70.1	19.2	71.3	19.4	73.9	19.6	76.4	19.9
	39	53.9	15.0	65.2	19.5	67.7	19.8	69.0	19.9	70.3	20.0	72.8	20.3	75.3	20.6
120%	10	49.8	7.19	62.2	9.07	74.7	11.0	80.9	12.1	84.8	12.5	87.1	11.9	89.4	11.4
	12	49.8	7.30	62.2	9.22	74.7	11.2	80.9	12.3	83.7	12.4	86.0	11.9	88.4	11.4
	14	49.8	7.43	62.2	9.39	74.7	11.4	80.9	12.5	82.6	12.4	84.9	11.9	87.3	12.0
	16	49.8	7.56	62.2	9.56	74.7	11.7	80.3	12.6	81.5	12.4	83.8	12.6	86.2	12.7
	18	49.8	7.69	62.2	9.73	74.7	12.0	79.2	13.0	80.4	13.1	82.7	13.2	85.1	13.4
	20	49.8	7.83	62.2	9.98	74.7	12.9	78.1	13.6	79.3	13.7	81.6	13.9	84.0	14.0
	21	49.8	7.90	62.2	10.3	74.7	13.3	77.6	14.0	78.8	14.0	81.1	14.2	83.4	14.3
	23	49.8	8.25	62.2	11.0	74.7	14.3	76.5	14.6	77.7	14.7	80.0	14.8	82.3	15.0
	25	49.8	8.79	62.2	11.8	74.2	15.1	75.4	15.2	76.6	15.3	78.9	15.5	81.2	15.7
	27	49.8	9.36	62.2	12.6	73.1	15.8	74.3	15.9	75.5	16.0	77.8	16.1	80.1	16.3
	29	49.8	9.97	62.2	13.4	72.0	16.4	73.2	16.5	74.4	16.6	76.7	16.8	79.0	17.0
	31	49.8	10.6	62.2	14.3	71.0	17.1	72.1	17.2	73.3	17.3	75.6	17.5	77.9	17.7
	33	49.8	11.3	62.2	15.2	69.9	17.7	71.0	17.8	72.2	17.9	74.5	18.1	76.8	18.3
	35	49.8	12.0	62.2	16.2	68.8	18.3	69.9	18.5	71.1	18.6	73.4	18.8	75.7	19.0
	37	49.8	12.7	62.2	17.3	67.7	19.0	68.8	19.1	70.0	19.2	72.3	19.5	74.6	19.7
	39	49.8	13.5	62.2	18.4	66.6	19.6	67.7	19.8	68.9	19.9	71.2	20.2	73.6	20.4
110%	10	45.6	6.59	57.0	8.27	68.4	10.0	74.1	11.0	79.8	11.9	85.6	12.3	87.7	11.8
	12	45.6	6.70	57.0	8.41	68.4	10.2	74.1	11.2	79.8	12.1	84.5	12.2	86.6	11.7
	14	45.6	6.81	57.0	8.56	68.4	10.4	74.1	11.4	79.8	12.3	83.4	12.2	85.5	12.0
	16	45.6	6.92	57.0	8.71	68.4	10.6	74.1	11.6	79.8	12.5	82.3	12.5	84.4	12.6
	18	45.6	7.04	57.0	8.87	68.4	10.8	74.1	11.9	79.0	13.0	81.2	13.1	83.3	13.2
	20	45.6	7.16	57.0	9.03	68.4	11.4	74.1	12.7	78.0	13.6	80.1	13.8	82.2	13.9
	21	45.6	7.22	57.0	9.19	68.4	11.8	74.1	13.2	77.4	13.9	79.5	14.1	81.7	14.2
	23	45.6	7.41	57.0	9.83	68.4	12.6	74.1	14.1	76.3	14.6	78.4	14.7	80.6	14.9
	25	45.6	7.89	57.0	10.5	68.4	13.5	74.1	15.1	75.2	15.2	77.3	15.4	79.5	15.5
	27	45.6	8.40	57.0	11.2	68.4	14.4	73.0	15.8	74.1	15.9	76.2	16.0	78.4	16.2
	29	45.6	8.93	57.0	11.9	68.4	15.4	72.0	16.4	73.0	16.5	75.2	16.7	77.3	16.9
	31	45.6	9.49	57.0	12.7	68.4	16.4	70.9	17.0	71.9	17.1	74.1	17.3	76.2	17.5
	33	45.6	10.1	57.0	13.5	68.4	17.5	69.8	17.7	70.8	17.8	73.0	18.0	75.1	18.2
	35	45.6	10.7	57.0	14.4	67.6	18.2	68.7	18.3	69.7	18.4	71.9	18.6	74.0	18.9
	37	45.6	11.3	57.0	15.3	66.5	18.9	67.6	19.0	68.6	19.1	70.8	19.3	72.9	19.5
	39	45.6	12.0	57.0	16.2	65.4	19.5	66.5	19.6	67.5	19.7	69.7	20.0	71.8	20.2
100%	10	41.5	6.01	51.8	7.49	62.2	9.07	67.4	9.88	72.6	10.7	83.0	12.4	86.0	12.2
	12	41.5	6.11	51.8	7.62	62.2	9.22	67.4	10.1	72.6	10.9	82.9	12.6	84.9	12.1
	14	41.5	6.20	51.8	7.75	62.2	9.39	67.4	10.2	72.6	11.1	81.8	12.5	83.8	12.1
	16	41.5	6.30	51.8	7.88	62.2	9.56	67.4	10.4	72.6	11.3	80.7	12.5	82.7	12.5
	18	41.5	6.41	51.8	8.02	62.2	9.73	67.4	10.6	72.6	11.5	79.6	13.0	81.6	13.1
	20	41.5	6.51	51.8	8.17	62.2	9.98	67.4	11.1	72.6	12.4	78.5	13.7	80.5	13.8
	21	41.5	6.57	51.8	8.24	62.2	10.3	67.4	11.5	72.6	12.8	78.0	14.0	79.9	14.1
	23	41.5	6.69	51.8	8.68	62.2	11.0	67.4	12.3	72.6	13.7	76.9	14.6	78.8	14.8
	25	41.5	7.05	51.8	9.26	62.2	11.8	67.4	13.2	72.6	14.7	75.8	15.3	77.7	15.4
	27	41.5	7.49	51.8	9.87	62.2	12.6	67.4	14.1	72.6	15.7	74.7	15.9	76.6	16.1
	29	41.5	7.96	51.8	10.5	62.2	13.4	67.4	15.0	71.7	16.4	73.6	16.5	75.5	16.7
	31	41.5	8.45	51.8	11.2	62.2	14.3	67.4	16.0	70.6	17.0	72.5	17.2	74.4	17.4
	33	41.5	8.96	51.8	11.9	62.2	15.2	67.4	17.1	69.5	17.7	71.4	17.8	73.3	18.0
	35	41.5	9.50	51.8	12.6	62.2	16.2	67.4	18.2	68.4	18.3	70.3	18.5	72.3	18.7
	37	41.5	10.1	51.8	13.4	62.2	17.3	66.3	18.9	67.3	19.0	69.2	19.2	71.2	19.4
	39	41.5	10.7	51.8	14.2	62.2	18.4	65.2	19.5	66.2	19.6	68.1	19.8	70.1	20.0

NOTES - ANMERKUNGEN - Σημειώσεις - NOTAS - REMARQUES - NOTE - OPMERKINGEN - примечания - NOTLAR

1 The above table shows the average value of conditions which may occur.
 Die obige Tabelle zeigt den Durchschnittswert der Bedingungen, die auftreten können.
 Στον παραπάνω πίνακα αναγράφεται η μέση τιμή για συνθήκες που μπορεί να προκύψουν.
 La tabla de arriba muestra el valor medio de condiciones que pueden ocurrir.
 Le tableau ci-dessus donne la valeur moyenne pour des conditions qui peuvent survenir.
 La tabella in alto mostra il valore delle condizioni medie che si possono riscontrare.
 De tabel hierboven geeft de gemiddelde waarde aan van situaties die kunnen voorvallen.
 Таблица расположенная выше показывает среднее значение условий, которые могут наступить.
 Yukarıdaki tablo meydana gelebilecek koşulların ortalama değerini göstermektedir.