

FXCQ-A

Model	Units			Power Supply		IFM		Input (W)	
	Hz	Volts	Voltage range	MCA	MFA	kW	FLA	Cooling	Heating
FXCQ20AVEB	50	220-240	Max. 264 Min. 198	0.3	16	0.046	0.2	31	28
FXCQ25AVEB				0.3	16	0.046	0.2	39	35
FXCQ32AVEB				0.3	16	0.046	0.2	39	35
FXCQ40AVEB				0.3	16	0.046	0.2	41	37
FXCQ50AVEB				0.4	16	0.046	0.3	59	56
FXCQ63AVEB				0.5	16	0.106	0.4	63	60
FXCQ80AVEB				0.6	16	0.046 +	0.5	90	86
FXCQ125AVEB				1.1	16	0.106 +	0.9	149	146

SYMBOLS

- MCA : Min. Circuit Amps (A)
MFA : Max. Fuse Amps (See note 5)
kW : Fan Motor Rated Output (kW)
FLA : Full Load Amps (A)
IFM : Indoor Fan Motor

NOTES

- Voltage range
Units are suitable for use on electrical systems where voltage supplied to unit terminals is not below or above listed range limits.
- Maximum allowable voltage unbalanced between phase is 2%
- MCA/MFA
 $MCA = 1.25 \times FLA$
 $MFA \leq 4 \times FLA$ (Next lower standard fuse rating. Min. 16A)
- Select wire size based on the MCA.
- Instead of fuse, use Circuit Breaker.

Minimum Ssc value	kVA	EN61000-3-2 is applied.
-------------------	-----	-------------------------