



NOTES

1 Overall (dB)

Scale	Mode		
	high	middle	low
A	46,0	42,0	38,0
C	52,5	48,8	45,2

(B,G,N is already rectified)

2 Measuring place: Anechoic chamber

3 Operation noise differs with operation and ambient conditions.

4 Operating conditions: Power source: 220-240V 50Hz

5 Cooling: Return air temperature: 27°CDB, 19°CWB

Outdoor temperature: 35°CDB, 24°CWB

6 Heating: Return air temperature: 20°CDB, 15°CWB

Outdoor temperature: 7°CDB, 6°CWB

7 Location of microphone

