

Unit size	Fan speed	Indoor air temperature					
		16,0 [°C DB]	18,0 [°C DB]	20,0 [°C DB]	21,0 [°C DB]	22,0 [°C DB]	24,0 [°C DB]
		TC	TC	TC	TC	TC	TC
10	High	1,5	1,4	1,3	1,2	1,2	1,1
	Medium	Correction factor $-0.92 \times H$					
	Low	Correction factor $-0.88 \times H$					
15	High	2,2	2,1	1,9	1,8	1,7	1,6
	Medium	Correction factor $-0.84 \times H$					
	Low	Correction factor $-0.79 \times H$					
20	High	2,9	2,7	2,5	2,4	2,3	2,1
	Medium	Correction factor $-0.84 \times H$					
	Low	Correction factor $-0.72 \times H$					
25	High	3,7	3,5	3,2	3,1	2,9	2,7
	Medium	Correction factor $-0.84 \times H$					
	Low	Correction factor $-0.72 \times H$					
32	High	4,7	4,3	4,0	3,8	3,7	3,3
	Medium	Correction factor $-0.85 \times H$					
	Low	Correction factor $-0.73 \times H$					
40	High	5,8	5,4	5,0	4,8	4,6	4,2
	Medium	Correction factor $-0.84 \times H$					
	Low	Correction factor $-0.72 \times H$					
50	High	7,4	6,8	6,3	6,0	5,8	5,3
	Medium	Correction factor $-0.81 \times H$					
	Low	Correction factor $-0.65 \times H$					
63	High	9,3	8,7	8,0	7,7	7,3	6,7
	Medium	Correction factor $-0.79 \times H$					
	Low	Correction factor $-0.63 \times H$					

Notes

- 1) TC: Total capacity [kW]
- 2) Outdoor temperature $-7^{\circ}\text{C DB} / -6^{\circ}\text{C WB}$