

		Indoor air temperature													
		14,0 [°C WB]		16,0 [°C WB]		18,0 [°C WB]		19,0 [°C WB]		20,0 [°C WB]		22,0 [°C WB]		24,0 [°C WB]	
		20,0 [°C DB]		23,0 [°C DB]		26,0 [°C DB]		27,0 [°C DB]		28,0 [°C DB]		30,0 [°C DB]		32,0 [°C DB]	
Unit size	Fan speed	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
15	H	1,0	0,8	1,3	1,0	1,5	1,1	1,7	1,2	1,9	1,2	2,2	1,3	2,5	1,4
	M	Correction factor ·0.86 × H·													
	L	Correction factor ·0.81 × H·													
20	H	1,3	1,0	1,6	1,3	2,0	1,5	2,2	1,5	2,4	1,6	2,8	1,7	3,3	1,8
	M	Correction factor ·0.89 × H·													
	L	Correction factor ·0.80 × H·													
25	H	1,6	1,3	2,1	1,6	2,5	1,9	2,8	1,9	3,1	2,0	3,6	2,1	4,2	2,2
	M	Correction factor ·0.92 × H·													
	L	Correction factor ·0.78 × H·													
32	H	2,1	1,7	2,7	2,0	3,3	2,4	3,6	2,5	3,9	2,5	4,6	2,7	5,4	2,9
	M	Correction factor ·0.88 × H·													
	L	Correction factor ·0.75 × H·													
40	H	2,6	2,2	3,3	2,6	4,1	3,0	4,5	3,1	4,9	3,2	5,8	3,4	6,7	3,6
	M	Correction factor ·0.87 × H·													
	L	Correction factor ·0.76 × H·													
50	H	3,2	2,7	4,1	3,2	5,1	3,7	5,6	3,8	6,1	4,0	7,2	4,2	8,3	4,5
	M	Correction factor ·0.88 × H·													
	L	Correction factor ·0.73 × H·													

Notes

- 1) TC: Total capacity [kW]
 SHC: Sensible heat capacity [kW]
 2) Outdoor temperature ·35·°C DB