

Recommended indoor units for ·REYA*A* + REMA5A*· outdoor units

.. HP	8	10	12	13	14	16	18	20
	4xFXSA50	4xFXSA63	6xFXSA50	3xFXSA50 3XFSA63	1xFXSA50 5XFSA63	4XFSA63 2xFXSA80	3xFXSA50 5XFSA63	8xFXSA63

For multi outdoor units ->16HP-, the recommended amount of indoor units is the sum of the indoor units defined for a single outdoor unit.

For details about the allowed combinations, see the engineering databook.

Appropriate indoor units for ·REYA*A* + REMA5A*· outdoor units

Covered by ·ENER LOT21·

FXFA20-25-32-40-50-63-80-100-125
FXZA15-20-25-32-40-50
FXSA15-20-25-32-40-50-63-80-100-125-140
FXDA10-15-20-25-32-40-50-63
FXAA15-20-25-32-40-50-63
FXMA50-63-80-100-125-200-250
FXHA32-50-63-100
FXUA50-71-100
FXKA20-25-32-40-50-63
FXNA20-25-32-40-50-63

Outside the scope of ·ENER LOT21·

EKVDX32-50-80-100
EKEXVA50-63-80-100-125-140-200-250-300-350-400-450-500 + EKEACBVE
CYAS100*80, CYAS150*80, CYAS200*100, CYAS250*140
CYAM100*80, CYAM150*80, CYAM200*100, CYAM250*140
CYAL100*125, CYAL150*200, CYAL200*250, CYAL250*250